NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
SEP 06 1985
WATER RESOURCES DEPT
~~SALEM, OREGON~~

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

MARI 13943
WWC Just found MARI
in his pickup
9/2/85

State Well No. 9S/2W-6AC
State Permit No.

(1) OWNER:
Name Charles Fowler Jr.
Address 4255 Cloverdale Road S.E.
Salem, OR 97392

(2) TYPE OF WORK (check):
New Well XX Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable XX Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation X Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded X
6" Diam. from +1 ft. to 31 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes X No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes XX No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes XX No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 60 gal./min. with 38 ft. ~~drawdown~~ pumping level after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 26 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 11 sacks
How was cement grout placed? Pumped.
Was a drive shoe used? XX Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes X No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes X No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number 605-170
SW ¼ NE ¼ Section 6 T. 9 S. R. 2 W. W.M.
Bearing and distance from section or subdivision corner
Sunnyside Fruit Farm #5, Lot 1 & 2

(11) WATER LEVEL: Completed well.
Depth at which water was first found 35 ft.
Static level 10 ft. below land surface. Date 7/8/83
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 65' 2" ft. Depth of completed well 65' 2" ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil, sand, loam	0	3	
Clay, brown	3	20	
Clay, brown, firm	20	29	
Rock, weathered basalt, brown	29	34	
Rock, basalt, blue, hard	34	65' 2"	10'

Work started July 6 1983 Completed July 8 1983
Date well drilling machine moved off of well July 10 1983

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] John L. Hoeck (Drilling Machine Operator) Date July 11, 1983
Drilling Machine Operator's License No. WWC No. 605

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Hoeck Well Drilling (Person, firm or corporation) (Type or print)
Address P.O. Box 1577, Eugene, OR 97440
[Signed] John L. Hoeck (Water Well Contractor)
Contractor's License No. 605 Date July 11, 1983

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119