NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the WATER WELL REPORT

WATER WELL REPORT

WATER RESOURCES DEPARTMED ECE VETTE OF OREGON

SALEM, OREGON 97310

Within 30 days from the date

of well completion.

Western Completion.

Western Completion.

State Permit No.

Meg/Ell (9) Welled Inc.				1
(1) OWNER: WATER RESOURCES DEPT.	(10) LOCATION OF WELL:			
Name Western ConmfseteMnoREGON	County Marion Driller's well n	umber J	D - 225	-79
Address PO BOX 45	NE ₁₄ NE _{14 Section} 36 _{T.} 4S	_{R.} 2W	********	W.M.
Canby, Or. 97013	Bearing and distance from section or subdivis			
(2) TYPE OF WORK (check):	June 1997	ion corne		
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐			***	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Denth at which water was first found 78			
Rotary Driven Domestic XXIndustrial Distriction D	Deput at which water was first found			
Cable		*		
	Artesian pressure lbs. per squa	re inch.	Date	
CASING INSTALLED: Threaded Welded 250 . 250	(12) WELL LOG: Diameter of well below casing 6)
"Diam. from ft. to 520 ft. Gage 250	(12) WELL LOG: Depth drilled 322 Diameter of well below casing 6 ft. Depth of completed well 322 ft.			
"Diam. from	Formation: Describe color, texture, grain size			
" Diam. from ft. to ft. Gage	and show thickness and nature of each stratu	ım and ac	guifer pe	netrated
PERFORATIONS: Perforated? Ves. No.	with at least one entry for each change of forma position of Static Water Level and indicate prin	tion, Repo	rt each (change in
Type of perforator used	MATERIAL	T		
The state of the s	topsoil	From	2	SWL
	clay brown	2	24	
perforations from	clay gray sandy	24	78	
perforations from ft. to ft.	sand black waterbearing	78	88	
	clay brown	88	107	
(7) SCREENS: Well screen installed? ☐ Yes 💆 No	sandstone brown WB	107	112	
Manufacturer's Name	clay gray	112	157	
Type Model No.	_sand gray WB	157	159	
Diam. Slot size Set from ft. to ft.	chy gray	159	171	
Diam. Slot size Set from ft. to ft.	sand blackheaving WB	171	189	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	_clay_gray	189	202	
•	_sand_blackheaving	202	213	
Was a pump test made? Yes No If yes, by whom?	_clay gray sticky	213	220	
yeld: 150 gal./min. with Total drawdown after 3 hrs.	_sand black heaving WB	220	- 265	
H H H	-clay gray sandy	265	- 285	
H " " " " " " " " " " " " " " " " " " "	sand black heaving WB	285	305	
Bailer test gal./min. with ft. drawdown after hrs.	gravel cemented	305	320	
Artesian flow g.p.m.	-gravel & blacksand WB	320	- 322	
perature of water Depth artesian flow encountered ft.	Work started 5-1 1979 Complete	5-5	-	₁₉ 79
(9) CONSTRUCTION:	Date well drilling machine moved off of well	5-5-		1979
cement			······································	
Well sealed from land surface to	Drilling Machine Operator's Certification: This well was constructed under my	direct	giinari	vision
Well sealed from land surface toft. Diameter of well bore to bottom of sealin	Waterials used and information reported	above a	re true	to my
Diameter of well bore to bottom of seal	best knowledge and belief	=	-7-7	α.
Number of sacks of cement used in well seal	[Signed] Machine Operator) Date 5-7-7919			
How was cement grout placed? pressure grouted	Drilling Machine Operator's License No	11	.69	
1 4	Western W. W. G.			
	Water Well Contractor's Certification:	-		1000
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Was a drive shoe used? Yes 🛘 No Plugs Size: location ft.	Name S & M DRILLING & SUPPLY, INC.			
Did any strata contain unusable water? Yes 🐴 No	(Dargon simm on company)	(Тур	e or print	t)
Type of water? depth of strata	Address \$99 SE Walnut Can	by, O	regor	2 970
Method of sealing strata off	[Signed] Walter Mar	10		
Was well gravel packed? [Yes KNo Size of gravel:	(Water Well Contra	ictor)		
Gravel placed fromft. toft.	Contractor's License No. 497 Date	5-7-		7,9