

RECEIVED
SEP 23 1959

MARION.....

74145
MARION

924-13

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

**STATE ENGINEER
SALEM, OREGON**

**WATER WELL REPORT
STATE OF OREGON**

State Well No. _____
State Permit No. _____

(1) OWNER:

Name West Stayton Grade School
Address Rt 1 Stayton, Ore.

(2) LOCATION OF WELL:

County MARION Owner's number, if any—
 $\frac{1}{4}$ Section 13 T. 9-S R. 2-W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from -2 ft. to 51 ft. Gage 280
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____

SIZE of perforations	in. by	in.
perforations from _____ ft. to _____ ft.		
perforations from _____ ft. to _____ ft.		
perforations from _____ ft. to _____ ft.		
perforations from _____ ft. to _____ ft.		
perforations from _____ ft. to _____ ft.		

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Type _____ Model No. _____
m. Slot size _____ Set from _____ ft. to _____ ft.
n. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Surface Depth of strata 20 ft.
Method of sealing strata off Drill and drive casing tightly.

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 9/12/57
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] Lois R. Rader Date 9/18, 1959
Marion Co. School
Rd # 61

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? _____

Yield:	gal./min. with	ft. drawdown after	hrs.
"	"	"	"
"	"	"	"
Bailer test	<u>40 gal./min. with</u>	<u>12 ft. drawdown after</u>	<u>1 hrs.</u>
Artesian flow			
g.p.m. Date _____			
Temperature of water			
Was a chemical analysis made? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

(12) WELL LOG:

Diameter of well 6 inches.

Depth drilled 51 ft. Depth of completed well 51 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay with few gravels partly fill material	0	4
Unconsolidated sandy clay and gravels to boulder size	4	25
Cemented sand and gravel	25	42
Loose, running sand some silt or clay-brown color	42	48
Loose sand and small gravels-quite clean (aquifer)	48	51

Work started 9/9 1959 Completed 9/12 1957

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WEST WELL DRILLING
(Person, firm, or corporation) (Type or print)

Address 4098 MARKET ST. N.E., SALEM

Driller's well number _____

[Signed] Marion E. West
(Well Driller)

License No. 30 Date 9/15, 1959