NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print) (Do not write above this line)

MAR 1 1967
STATE ENGINEER
SALEM, OREGON

MAR 1 1 43

State Well No. 3/1w-33N
State Permit No. G-4471

(1) OWNER:
Name A J Canby
Address R.I. Box 28
Aurora, Ore. 97002

(2) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):
Domestic [X] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

CASING INSTALLED:
Threaded [] Welded [X]
6 5/8" Diam. from 0 ft. to 100 ft. Gage .250
8" Diam. from 0 ft. to 160 ft. Gage .250
1 1/2" Bell Diam. from 160 ft. to 160-10 ft. Gage .250

PERFORATIONS:
Perforated? [X] Yes [] No
Type of perforator used Mills Knife
Size of perforations 3/16 in. by 2 in.
140 perforations from 136 ft. to 156 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 47 ft. below land surface Date 11-25-67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
gal./min. with ft. drawdown after hrs.
200 air lift 33' 8 "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [] No

(10) CONSTRUCTION:
Well seal—Material used Bentonite
Depth of seal 25 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [] Yes [X] No
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [X] Yes [] No Size of gravel: 3/4 to 1/4
Gravel placed from 0 ft. to 160 ft.

(11) LOCATION OF WELL:
County Marion Driller's well number
¼ ¼ Section 33 T. 3S R. 1W W.M.
Bearing and distance from section or subdivision corner
1 mi East of Butteville

(12) WELL LOG:
Diameter of well below casing
Depth drilled 160 ft. Depth of completed well 160 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	2	
Red Clay	2	14	
Silty Brown Clay	14	28	14'
Blue Clay	28	42	
Soft Blue Clay	42	56	32'
" "	56	68	
Silty Blue Clay	68	82	
Brown Clay	82	98	
Light Brown Clay			
with small gravel	98	107	
Brown Clay	107	112	
Silty Blue Clay	112	134	
Sand & gravel	134	146	52½'
Blue Clay	146	148	
gray sand some gravel	148	157	47'
Hard Blue Clay	157	160	

Work started 10-16-67 Completed 11-25 19 67
Date well drilling machine moved off of well 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Mike Schneider Date 12-1-67, 19
(Drilling Machine Operator)
Drilling Machine Operator's License No. 212

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Mike Schneider Equip. Co. (Person, firm or corporation) (Type or print)
Address Star Route Box 97 St. Paul Ore
[Signed] Mike Schneider (Water Well Contractor)
Contractor's License No. 387 Date 12-1-67, 19

(USE ADDITIONAL SHEETS IF NECESSARY)