

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
WATER WELL REPORT
RECEIVED

DEC 19 1977
STATE OF OREGON

(Please type or print)

WATER RESOURCES DEPT.
SALEM, OREGON

(Do not write above this line)

JAN 6 1978

State Well No.

State Permit No.

184509
98/2W-28

MARI

(1) OWNER:

Name JAMES WOEZEL
Address 3290 Liberty RD SE
Salem Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 20 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" with 100 ft. drawdown after hrs.

Bailer test 8 gal./min. with ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 6.9 in.
Diameter of well bore below seal in.

Number of sacks of cement used in well seal 4 sacks

How was cement grout placed? put in hole

up + down the pusher casing

also the cement

Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County MARION Driller's well number
1/4 1/4 Section 28 T. 9S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 110 ft.
Static level 90 ft. below land surface. Date 11/17/77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 296 ft. Depth of completed well 296 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
BROWN CLAY	0	8	
BROWN STONE	8	13	
BLACK BASALT	13	32	
BROWN BASALT	32	35	
BLACK BASALT	35	37	
BROWN BASALT	37	41	
BLACK BASALT	41	110	
BROWN BASALT	110	119	
BLACK BASALT	119	126	
BROWN BASALT	126	133	
BLACK BASALT	133	296	

Work started OCT 11 19 77 Completed OCT 16 19 77

Date well drilling machine moved off of well OCT 11 19 77

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Melvin Search Date Nov 3, 19 77
(Drilling Machine Operator)

Drilling Machine Operator's License No. 699

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name MELVIN SEARCH WELLD RILLING
(Person, firm or corporation) (Type or print)

Address P.O. Box 433 FEBANDORE

[Signed] Melvin Search
(Water Well Contractor)

Contractor's License No. 567 Date Nov 3, 19 77