

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

State Well No. 9/2w-354

State Permit No. G-7067

MARI... 14552 MARI

290

(1) OWNER:

Name ROBERT MADSEN Address 590 VISTA AVE. S.E. SALEM ORE.

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Cable [ ] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:

6" Diam. from 0 ft. to 20 ft. Gage 17.02 NO WEEDS Threaded [ ] Welded [ ]

PERFORATIONS:

Perforated? [ ] Yes [X] No. Type of perforator used Size of perforations in. by in.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 58' ft. below land surface Date 4-11-68 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? SNEED BROS. 35 gal./min. with 100' ft. drawdown after 1 1/2 hrs.

Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 57° Was a chemical analysis made? [ ] Yes [X] No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE Depth of seal 19 1/2' ft. Diameter of well bore to bottom of seal 9 1/2' in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [ ] Yes [X] No Did any strata contain unusable water? [ ] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MARION Driller's well number NE 1/4 NE 1/4 Section 30 T.9S R. 2W W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 162' ft. Depth of completed well 162' ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include TOPSOIL, CLAY YELLOW, BASALT WEATHERED, SANDSTONE GRAY HARD, LIMESTONE - HARD, CLAYSTONE GRAY - HARD, SANDSTONE HARD.

WATER ENTERS WELL FROM 147' TO 160'

Work started 4-11-1968 Completed 4-11-1968 Date well drilling machine moved off of well 4-11-1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] R.F. Sneed Date 4-11-1968 (Drilling Machine Operator)

Drilling Machine Operator's License No. 187

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME J.A. SNEED & SONS (Person, firm or corporation) (Type or print) Address 3910 SILVERTON RD SALEM ORE [Signed] R.F. Sneed (Water Well Contractor) Contractor's License No. 6 Date 4-11-1968