

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON
Please type or print
(Do not write above this line)

State Well No. 3/1w-33

State Permit No. Pg 1 of 2

RECEIVED
JUL 18 1968
STATE ENGINEER
SALEM, OREGON

PRELIMINARY REPORT

(1) OWNER:

Name Century Meadows
Address 2117 B. Rd. 16
Wasson Ave 97003

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 173 ft. Gage 250
8" Diam. from 0 ft. to 173 ft. Gage 250
6" Diam. from 0 ft. to 100 ft. Gage 250

PERFORATIONS:

one along side of other
Type of perforator used Torch Perforated? Yes No
Size of perforations 3/8 in. by 4 in.
on 12" - 480 perforations from 120 ft. to 160 ft.
on 8" - 320 perforations from 120 ft. to 160 ft.

(7) SCREENS: Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level _____ ft. below land surface Date _____
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____
Well: _____ gal./min. with _____ ft. drawdown after _____ hrs.
Not tested or developed at this date
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Concrete
Depth of seal 100' ft.
Diameter of well bore to bottom of seal 9 1/4" in.
Were any loose strata cemented off? Yes No Depth see log
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off Concrete
Was well gravel packed? Yes No Size of gravel: 3/4 - 3/8"
Gravel placed from 100' ft. to 173' ft.

(11) LOCATION OF WELL:

County Marion Driller's well number _____
1/4 Section 33 T. 35 R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 173 ft. Depth of completed well 170 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top	0	4	
Brown Clay	4	20	
Light tan Brown Clay	20	34	
Bluish Clay	34	40	
Brown Clay	40	76	
Blue	76	82	
Crumbly Blue Clay	82	87	
Grey	87	88	
Brown	88	94	
Blue	94	97	
Brown	97	101	
Blue	101	123	
Black sand	123	146	
Brown sand	146	144	
Blue Clay	144	148	
Grey Clay streaks of light	148	163	
Light Blue Clay	163	165	
Brown	165	166	
Blue	166	173	

Work started 6-17 1968 Completed _____ 19____
Date well drilling machine moved off of well 7-2 68

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Kirk Kahle Date 7-15-68
(Drilling Machine Operator)

Drilling Machine Operator's License No. 505

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Mick Schneider Equip Co
Address Star Route Box 97 B. Paul
[Signed] Mick Schneider
(Water Well Contractor)

Contractor's License No. 387 Date 7-15-68

NC

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON
within 30 days from the date
of well completion.

WATER WELL REPORT
STATE OF OREGON

MARI...146

State Well No. 3/1w-33
State Permit No. Pg 2 of 2

RECEIVED
SEP 16 1968

(1) OWNER: STATE ENGINEER

Name Century Meadows
Address 101 Meadow Drive
Hussey, Ore. 97002

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Driven
Cable Jetted
Dug Bored
(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:
12" Diam. from 0 ft. to 173 ft. Gage 250
8" Diam. from 0 ft. to 173 ft. Gage 250
6" Diam. from 0 ft. to 173 ft. Gage 250

PERFORATIONS: *one at 120 ft. for test*
Type of perforator used Tech
Size of perforations 3/8 in. by 6 in.
on 12" 480 perforations from 120 ft. to 160 ft.
on 8" 320 perforations from 120 ft. to 160 ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 56 ft. below land surface Date 8-6-68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
400 gal./min. with 97 ft. drawdown after 6 hrs.
on airlift 8-6-68

Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:
Well seal—Material used concrete
Depth of seal 100 ft.
Diameter of well bore to bottom of seal 24 in.
Were any loose strata cemented off? No Depth 100 ft.
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off concrete
Was well gravel packed? Yes No Size of gravel: 3/4-3/8
Gravel placed from 100 ft. to 173 ft. 46" jet

(11) LOCATION OF WELL:

County Marion Driller's well number
1/4 Section 23 T. 55 R. 1W W.M.
Bearing and distance from section or subdivision corner
1480N and 75E of S.W. cor
of Sec 33

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 173 ft. Depth of completed well 170 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
top	0	4	
brown clay	4	20	
light fclty brown clay	20	34	
blue clay	34	40	
brown clay	40	76	
blue clay	76	82	
assembly blue clay	82	87	
grey clay	87	88	
brown clay	88	94	
blue clay	94	97	
brown clay	97	101	
blue clay	101	129	
black sand	129	140	
light blue clay	140	144	
blue clay	144	148	
grey clay	148	163	
light blue clay	163	165	
brown clay	165	166	
blue clay	166	173	

Work started 6-17 1968 Completed 8-26 1968
Date well drilling machine moved off of well 8-26 1968

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Rick Kahle Date 8-26 68
(Drilling Machine Operator)

Drilling Machine Operator's License No. 505

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Mike Schneider Equipment Co
(Person, firm or corporation) (Type or print)
Address 5099 S. Paul Ave
[Signed] Mike Schneider
(Water Well Contractor)

Contractor's License No. 387 Date 8-26-68