

STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.765)

**RECEIVED**

APR 23 1986

PLEASE TYPE OR PRINT IN INK

MAR 11 1986

24749

85/3W-1ad

**WATER RESOURCES DEPT**

(for official use only)

**(1) OWNER:**

Name Poole's Inc. Trailer Home Park  
 Address 3100 Turner Road SE  
 City Salem State OR 97302

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary Air  Driven   
 Rotary Mud  Dug   
 Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Thermal: Irrigation  Withdrawal  Reinjection   
 Other: Piezometric  Grounding  Test

**(5) CASING INSTALLED:**

Steel  Plastic   
 Threaded  Welded   
 8" Diam. from +2 ft. to 137 ft. Gauge .250  
 " Diam. from ft. to ft. Gauge .277 top 14'

**LINER INSTALLED:**

Steel  Plastic   
 Threaded  Welded

**(6) PERFORATIONS:**

Perforated?  Yes  No  
 Size of perforations in. by in.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 Type \_\_\_\_\_ Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 gal./min. with ft. drawdown after hrs.  
 Air test 520 gal./min. with drill stem at 460 ft. 1 hrs.  
 Bailer test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m.  
 Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Special standards: Yes  No   
 Well seal—Material used Cement  
 Well sealed from land surface to 137 ft.  
 Diameter of well bore to bottom of seal 12" to 29' 10" - 132' to 137'  
 Diameter of well bore below seal 8 in.  
 Amount of sealing material 59 sacks  pounds   
 How was cement grout placed? Pressure grouted  
 Was pump installed? No Type \_\_\_\_\_ HP \_\_\_\_\_ Depth \_\_\_\_\_ ft.  
 Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of Water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL by legal description:**

County Marion SE 1/4 NE 1/4 of Section 1 of  
 Township 8 South Range 3 West WM.  
 (Township is North or South) (Range is East or West)  
 Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 MAILING ADDRESS OF WELL (or nearest address)  
Same as #1.

**(11) WATER LEVEL of COMPLETED WELL:**

Depth at which water was first found 167 ft.  
 Static level 33 ft. below land surface. Date 4/11/86  
 Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 7 7/8"  
 Depth drilled 461 ft. Depth of completed well 461 ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil & small gravel	0	2	
Medium conglomerate brown	2	30	
Conglomerate green harder	30	37	
Conglomerate brown (more gravel)	37	44	
Conglomerate brown soft (more clay)	44	47	
Clay blue and gravel	47	57	
Conglomerate brown	57	70	
Clay brown	70	79	
Conglomerate	79	85	
Clay reddish brown	85	129	
Weathered basalt reddish brown	129	132	
Basalt grey hard	132	158	
Basalt weathered reddish brown	158	167	
Basalt grey hard w/ fx. seams	167	291	WB
Basalt porous seamy	291	298	
Basalt grey hard fractured	298	302	
Basalt grey porous w/green seams	302	306	
Basalt grey hard fractured	306	313	WB
Basalt grey fx. porous w/green seams	313	323	WB
Basalt grey hard fractured seams and occasional colored fx. seams.	323	461	WB

Date work started 2/25/86 /completed 4/11/86  
 Date well drilling machine moved off of well 4/12/86 19

**(unbonded) Water Well Constructor Certification (if applicable):**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Don Stadel Date 4-14, 1986

**(bonded) Water Well Constructor Certification:**

Bond 5122718 Issued by: Safeco Insurance of America  
 (number) (Surety Company Name)  
 On behalf of R. Stadel & Sons, Inc.  
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Paul R. Stadel  
 (Water Well Constructor)

(Dated) 4-17-86

NOTICE TO WATER WELL CONSTRUCTOR  
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
 SALEM, OREGON 97310  
 within 30 days from the date of well completion.

SP\*46866-690