

RECEIVED
 SEP 7 1966
 WATER WELL REPORT
 STATE ENGINEER STATE OF OREGON
 SALEM, OREGON

14834

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

State Well No. 9/36-2
 State Permit No. _____

(1) OWNER:
 Name E. C. WENDLAND
 Address Rt. 1 Box 26th Drive S.E. SALEM ORE.

(2) LOCATION OF WELL:
 County MARION Driller's well number _____
 1/4 Section 2 T. 9S R. 3W W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
 6" Diam. from 0 ft. to 33'6" ft. Gage 17.02
 " Diam. from " ft. to " ft. Gage _____
 " Diam. from " ft. to " ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used _____
 Size of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Slot size _____ Set from _____ ft. to _____ ft.
 Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
 Well seal—Material used in seal BENTONITE
 Depth of seal 32'6" ft. Was a packer used? yes
 Diameter of well bore to bottom of seal 9 1/2" in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:
 Static level 21 ft. below land surface Date 9-1-66
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? SNPDS BRDS
 Yield: 60 gal./min. with 180 ft. drawdown after 2 hrs.
 " " " " " "
 " " " " " "
 Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 53° Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 6"
 Depth drilled 327 ft. Depth of completed well 327 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	2
CLAY YELLOW COLOR	2	6
BASALT WEATHERED-HARD	6	12
CLAY GRAY COLOR-STICKY	12	22
SANDSTONE GRAY HARD	22	34
CLAYSTONE FIRM	34	80
SANDSTONE GRAY HARD	80	90
CLAYSTONE FIRM	90	110
SANDSTONE GRAY HARD	110	123
CLAYSTONE FIRM	123	160
SANDSTONE GRAY HARD	160	198
CLAYSTONE FIRM	198	314
SANDSTONE GRAY HARD	314	327

Work started 8-31-1966 Completed 9-1-1966
 Date well drilling machine moved off of well 9-1-1966

(13) PUMP:
 Manufacturer's Name _____ Type: _____ H.P. _____
Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 NAME J. A. SHEED & SONS
 (Person, firm or corporation) (Type or print)
 Address 3910 SILVERTON RD. SALEM ORE.
 Drilling Machine Operator's License No. 187
 [Signed] B. F. Sheed
 (Water Well Contractor)
 Contractor's License No. 6 Date 9-1-1966