

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print) (Do not write above this line)

STATE ENGINEER

MAR. 1967
State Well No. 5/1w-4
State Permit No.

(1) OWNER:

Name Ivan L. Orton Chateau Village
Address Rt. 1 Woodburn, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
8" Diam. from top ft. to 170 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills
Size of perforations 2 in. by 3/8 in.
80 perforations from 163 ft. to 170 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No.
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 50 ft. below land surface Date 9/7/67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 100 gal./min. with 20 ft. drawdown after 4 hrs.
85 " 15 " 4 "
70 " 10 " 4 "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 56 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement & Puddle clay
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 1260
1/4 1/4 Section 4 T. 5 R. 1W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing
Depth drilled 170 ft. Depth of completed well 170 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil	0	2	
Yellow clay	2	45	
Blue clay	45	80	
Black sand	80	102	40
Gray sandy clay	102	115	
Gravel	115	120	50
Blue clay	120	150	
Gravel	150	170	50

Work started 8/22/67 19 Completed 9/7/67 19
Date well drilling machine moved off of well 9/8/67 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Donald W. Matton Date 9/7/67, 19.....
(Drilling Machine Operator)

Drilling Machine Operator's License No. 536

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY
(Person, firm or corporation) (Type or print)

Address Rt. 2 Box 276, Salem, Oregon

[Signed] Ernie O. Beer
(Water Well Contractor)

Contractor's License No. 2 Date 9/7/67, 19.....