

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**WATER WELL REPORT**

STATE OF OREGON  
(Please type or print)

(Do not write above this line)

M 1.21...  
100  
5047  
State Well No. 95/3w-14  
State Permit No. G-9371

(1) OWNER:  
Name David Klein  
Address 1410 Court St. N.E.  
Salem, OR 97301

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary  Driven   
Jetted  Bored   
(4) PROPOSED USE (check): Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED: Threaded  Welded   
6" Diam. from +1 ft. to 52 ft. Gage 1250  
4" Diam. from 0 ft. to 296 ft. Gage PK110

(6) PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used Saw  
Size of perforations 1/8 in. by 7 in.  
66 perforations from 236 ft. to 276 ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
Pump test 21 gal./min. with 196 ft. drawdown after 2 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION: Well seal—Material used Cement grout  
Well sealed from land surface to 52 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 26 sacks  
How was cement grout placed? pumped to bottom of annulus  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:  
County Marion Driller's well number \_\_\_\_\_  
1/4 1/4 Section 14 T. 9S R. 3W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 273 ft.  
Static level 77 ft. below land surface. Date 5-30-80  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6  
Depth drilled 300 ft. Depth of completed well 296 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Brown Clay	1	8	
Grey Sandstone	8	43	
Hard Sandstone	43	123	
Brown Sandstone	123	157	
Grey Sandstone	157	270	
Fractured Grey Sandstone	270	300	

Work started 5-27 1980 Completed 5-30 1980  
Date well drilling machine moved off of well 5-30 1980

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Kurt M. Palmer Date 5-30, 1980  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 1330

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name AQUA-TECH Well Construction Inc.  
(Person, firm or corporation) (Type or print)  
Address 868 Delta Dr. NE Salem  
[Signed] David Beach  
(Water Well Contractor)  
Contractor's License No. 696 Date June 10, 1980