WATER WELL REPORT
STATE OF OREGON

MART... 15061

RECEIVED
JUN 6 1983
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 9S/3W-15
State Permit No. .....
address is 768

(1) OWNER:

Name DON WILLIAMSON
Address 118 N.E. FERN AVE
City DALLAS State OR. 97338

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☐ Driven ☐
Rotary Mud ☐ Dug ☐
[redacted] ☒ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:

Steel ☒ Plastic ☐
Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 24 ft. Gauge 7/"
" Diam. from ft. to ft. Gauge

[redacted] LINER INSTALLED: NONE

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?
[redacted]: gal./min. with ft. drawdown after hrs.
" " " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test 30 gal./min. with 6 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
[redacted]perature of water 51° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes ☐ No ☒
Well seal—Material used CEMENT
Well sealed from land surface to 23' 6" ft.
Diameter of well bore to bottom of seal 10" in.
Diameter of well bore below seal 6" in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? THROUGH CONDUCTOR PIPE

Was pump installed? NO Type HP Depth ft.
Was a drive shoe used? ☐ Yes ☒ No Plugs NO Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County MARION Driller's well number
¼ ¼ Section 15 T. 9S R. 3W W.M.
Tax Lot # Lot 3 Blk 2 Subdivision MEADOW LANE
Address at well location: 798 MEADOW LANE S.E
JEFFERSON OR. 97352

(11) WATER LEVEL: Completed well.

Depth at which water was first found 231' ft.
Static level 80 ft. below land surface. Date 6-2-83
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 238 ft. Depth of completed well 238 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOPSOIL	0	2	
BASALT WEATHERED	2	19	
CLAYSTONE GRAY HARD	19	80	
SANDSTONE LIGHT GRAY	80	85	
CLAYSTONE GRAY HARD	85	231	
SANDSTONE FRACTURED HARD LIGHT GRAY	231	238	80'

Work started 5-16 1983 Completed 6-2 1983
Date well drilling machine moved off of well 6 2 1983

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] R.F. Sneed (Drilling Machine Operator) Date 6-2, 1983
Drilling Machine Operator's License No. 187

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name R.F. SNEED WELL DRILLING (Person, firm or corporation) (Type or print)
Address 4750 ELIZABETH N. SALEM OR.
[Signed] R.F. Sneed (Water Well Contractor)
Contractor's License No. 6 Date 6-2, 1983

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690