

RECEIVED

FEB 11 1965

MARIAN 157.9

5/1w-4D

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON
within 30 days from the date
of well completion.

STATE ENGINEER STATE OF OREGON
SALEM, OREGON (Please type or print)

State Well No. _____

State Permit No. _____

(1) OWNER:

Name Bronic Bros.
Address Hubbard, Oregon

(2) LOCATION OF WELL:

County Marian Driller's well number _____
1/4 1/4 Section 5 T. 5S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
16" Diam. from 0 ft. to 131 ft. Gage 1/4"
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Millknife
Size of perforations 3/8 in. by 2 in.
358 perforations from 108 ft. to 124 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled Mud
Depth of seal 20 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 16 ft. below land surface Date 1/15/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? driller
Yield: 500 gal./min. with 72 ft. drawdown after 8 hrs.
" 600 " " 85 " " 8 "
" 800 " " 100 " " 4 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 131 ft. Depth of completed well 131 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface	0	3
Brown sandy clay	3	37
Blue sandy clay	37	68
Small gravel	68	70
Blue sandy clay	70	99
Black sand	99	107
Broken gravel	107	124
Blue clay	124	131

Work started Nov 16 1964, Completed Jan 15 1965
Date well drilling machine moved off of well 19 _____

(13) PUMP:

Manufacturer's Name _____
Type _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller
(Person, firm or corporation) (Type or print)
Address P O Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 277 26
[Signed] John T. Miller
(Water Well Contractor)
Contractor's License No. 26 Date Feb. 6, 1965