WATER WELL REPORT STATE OF OREGON

JAN271981

WATER RESOURCES DEP SALEM, OREGON



State Well No. 95 - 3w - 33 ad

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name Arthur White	County Marion Driller's well number
Address 14013 Westside Lane S.	SE 14 NE 14 Section 33 T. 9S R. 3W W.M.
City Jefferson State Oregon	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: 14013 Westside Lane South Jefferson, Oregon 97352
New Well ☑ Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 18 ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 9 ft. below land surface. Date 1/14/8
Air Air Driven Domestic Industrial Municipal Rotary Mud Dug Irrigation X Test Well Dother I	Artesian pressure lbs. per square inch. Date
Cable Bored Thermal: Withdrawal Reinjection	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic	Depth drilled 30 ft. Depth of completed well 30 ft.
Threaded □ Welded 🖾	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry
7 Diam from +1 ft. to 30 ft. Gauge 250	for each change of formation. Report each change in position of Static Water Level
	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
ft. Gauge	Top Soil 0 2
(6) PERFORATIONS: Perforated? \(\Delta\) Yes \(\Delta\) No	Sandy Loam 2 6
Type of perforator used	Med & Large Gravel Cemented 6
Size of perforations 14 in. by 6 in.	(Silty) 18
100 perforations from 19 ft. to 29 ft.	Med & Large Sand & GravelW.B.18 30 9'
perforations from	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? ☐ Yes 🛎 No. Manufacturer's Name	
Type	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
Drawdown is amount water level is lowered	
WELL TESTS: below static level	
Was a pump test made? ☐ Yes ☒ No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
" " " "	
gal./min. with drill stem at 30 ft. 1 hrs.	
fer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
Temperature of water 54 Depth artesian flow encountered ft.	Work started 1/12/81 19 Completed 1/14 19 81
(9) CONSTRUCTION: Special standards: Yes □ No 🖾	Date well drilling machine moved off of well $1/14$ 19 81
Well seal—Material used Cement	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal	and information reported above are true to my best knowledge and belief. [Signed] Juoue M. Jurgann Date 1/15 19 81
Diameter of well bore below seal 12in.	(Brilling Machine Operator)
Number of sacks of cement used in well seal 19 sacks	Drilling Machine Operator's License No. 10.72
How was cement grout placed?FromBottomtotop	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to
Was pump installed? NO. Type HP Depth ft.	the best of my knowledge and belief.
Was a drive shoe used? Yes □ No Plugs	Name Schoen Electric, Inc.
Did any strata contain unusable water? Yes No	Address 626 West Queen Ave Albany, Oregon 9/321
Type of Water? depth of strata	4/4/2
Method of sealing strata off	[Signed] (Water Well Contractor)
Was well gravel packed? ☐ Yes 🖾 No Size of gravel:	Contractor's License No. 513 Date 1/15/ 19.81
Gravel placed from	TOTAL