

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

**WATER WELL REPORT**

STATE OF OREGON (Please type or print)

State Well No. 5/1W-5

State Permit No. \_\_\_\_\_

MARI. 154/

**(1) OWNER:**

Name Robert Gregory  
 Address Rte 1 Box 27A  
Woodburn, Oregon

**(2) LOCATION OF WELL:**

County Marion Driller's well number \_\_\_\_\_  
1/4 1/4 Section 5 T. 5S R. 1W W.M.  
 Bearing and distance from section or subdivision corner \_\_\_\_\_

**(3) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 abandonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**(5) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(6) CASING INSTALLED:**

Threaded  Welded

6 " Diam. from 0 ft. to 122 ft. Gage 1 1/4"  
 \_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 \_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:**

Perforated?  Yes  No

Type of perforator used \_\_\_\_\_  
 Size of perforations in. by in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:**

Well screen installed  Yes  No

Manufacturer's Name \_\_\_\_\_  
 Type \_\_\_\_\_ Model No. \_\_\_\_\_  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used in seal Bentonite Mud  
 Depth of seal 25 ft. Was a packer used? no  
 Diameter of well bore to bottom of seal 10 in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**

Static level 16 ft. below land surface Date 12/23/62  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? driller  
 Yield: 90 gal./min. with 50 ft. drawdown after 8 hrs.  
 " " " " " "  
 " " " " " "  
 Bailer test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m. Date \_\_\_\_\_  
 Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well below casing 6

Depth drilled 122 ft. Depth of completed well 122 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
surface	0	3
brown sandy clay	3	48
blue sandy clay	48	69
course black sand	69	76
blue sandy clay	76	98
black sand	98	112
broken sand and gravel	112	122

Work started Dec 17 19 62 Completed Dec 22 19 62  
 Date well drilling machine moved off of well \_\_\_\_\_ 19 \_\_\_\_\_

**(13) PUMP:**

Manufacturer's Name \_\_\_\_\_  
 Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller  
 (Person, firm or corporation) (Type or print)

Address P.O. Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 277 26

[Signed] John Truman Miller  
 (Water Well Contractor)

Contractor's License No. 26 Date February 9, 19.63.