MARI 15505

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
JUN 25 1980
WATER RESOURCES DEPT
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

15505 MARI

State Well No. 8S/3W-36

State Permit No.

(1) OWNER:
Name Paul Vatrus
Address 8372 Enchanted Way S.E.
Turner, Oregon

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 11 ft. to 68 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
"Air Test may Fluctuate "
Bailer test 200+ gal./min. with 169 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 68 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? Halliburton method
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
¼ ¼ Section 36 T. 9S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 86 ft.
Static level 19 ft. below land surface. Date 4-7-80
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 188 ft. Depth of completed well 188 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Red Clay	1	6	
Tan Clay	6	15	
Decomposed Rock	15	18	
Badly Weathered Basalt	18	62	
Weathered Basalt	62	79	
Basalt gray	79	125	
Broken Basalt	125	182	
Badly Broken Basalt	182	188	19'
86 ft. 1 G.P.m.			
102'-105' 8 G.P.m			
125'-128' 11 G.P.m.			
139'-144' 40 G.P.m.			
170'-188' 140+ G.P.m			

Work started 4-4 1980 Completed 4-7 1980
Date well drilling machine moved off of well 4-7 1980

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] T.D. Monders (Drilling Machine Operator) Date 4-8, 1980
Drilling Machine Operator's License No. 1195

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Miller West Well Drilling (Person, firm or corporation) (Type or print)
Address 5875 Gaffin Rd. Salem
[Signed] Marc Monders (Water Well Contractor)
Contractor's License No. 746 Date 4-8, 1980

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119