NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON

WATER WELL REPORT CEIVED

DEC 131977 State Well No. 95 1E-960

(Please type or print) TOR RESOURCES State Permit No. ....
(Do not write above this line) SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name Mrs. Frank Peters	County Marion Driller's well number		
Address 17485 Old Mehema Rd. S.E.	S.E. 1/2 N.W. 4/4 Section 9 T. 9, S. R. 1 E. W.M.		
Stayton, Oregon 97383	Bearing and distance from section or subdivisi		1,1222
(2) TYPE OF WORK (check):	g subuly an	011 0011101	
New Well 🕻 Deepening 🗌 Reconditioning 🗍 Abandon 🗍			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	vall	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	newhork with the state of a name of the state of the stat		
Potows III Parlian II			
Cable 🛣 Jetted 🛘 Domestic 📝 Industrial 📋 Municipal 📋		surface. Date 1	1/9/77
Dug Bored I Irrigation C Test Well Other	Artesian pressure XX lbs. per squar	e inch. Date	
CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well h		6"
6 " Diam from 1+ ft. to 195 ft. Gage •250	Diameter of well below casing		
	Depth drilled 213 ft. Depth of completed well 213 ft.		
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,		
DEDUCTOR A MYOLYG	with at least one entry for each change of formation. Report each change in		
PERFORATIONS: Perforated? X Yes \( \square\) No.	position of Static Water Level and indicate prin	cipal water-beari	ng strata.
Type of perforator used Mills Knife	MATERIAL	From To	swL
Size of perforations 🗼 in. by 3 in.	Top soil-redish- brn	0 1	5
234 perforations from 65 ft. to 103 ft.	Clay- red-	1 15	
258 perforations from 103 ft. to 189 ft.	Medconglomred.med.hd	15 21	
perforations from ft. to ft.	Med,-conglom,-grey-" "	21 63	
	Coarse- conglomgrey-med.hd	63 92	
(7) SCREENS: Well screen installed?   Yes  No	Med conglombrn		(W.B.)
Manufacturer's Name	Med conglom green-	135 205	
Type Model No.	Med conglom yellow-	205 210	<del> </del>
Diam. Slot size Set from ft. to ft.	Med conglom green-	210 213	
Diam Slot size Set from ft. to ft.	zoong congressive purcous	220 22	<del>-</del>
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? [XYes [] No If yes, by whom? Drillers			-
Weld: 85 gal./min. with 75 ft. drawdown after 5 hrs.			
" " " " "			
<u> </u>			·
Bailer test 35 gal./min. with 35 ft. drawdown after 1 hex			
Artesian flow g.p.m.			
hperature of water XX Depth artesian flow encountered ft.	Work started 10/8/77 19 Complete	d 11/9/77	19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	11/9/77	19
Vell seal—Material used	Drilling Machine Operator's Certification:		
Vell sealed from land surface to		direct super	vigion
	This well was constructed under my direct supervision.  Materials used and information reported above are true to my		
Diameter of well bore to bottom of seal	best knowledge and belief.		
	[Signed] (Drilling Machine Operator) 19.77		
29	Drilling Machine Operator's License No		
Now was cement grout placed? Gravity Fressure	Diming Machine Operator's Literise IVO.		
The state of the s	Water Well Contractor's Certification:		
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Vas a drive shoe used? 🗗 Yes 🗌 No Plugs Size: location ft.	Name R. Stadeli & Sons. The.		
old any strata contain unusable water? 🗌 Yes 🕦 No	Name R. Stadeli & Sons. Inc.  11364 (Person, firm or corporation) (Type or print)		
ype of water? depth of strata	Address EyergreenEd.N.E.,Silverton,Ore.,97381		
Method of sealing strata off			
Was well gravel packed? [ Yes X No Size of gravel:	[Signed] Jaw. A. Stattle (Water Well Contractor)		
Gravel placed fromft. toft.	Contractor's License No. 296 Date 12/7/7 7 19		