

NOTICE TO WATER WELL CONTRACTOR  
The original and first  
of this report are to  
be filed with the

RECEIVED MAR 15 1968 WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON (Please type or print)  
within 30 days from the date of well completion. SALEM, OREGON Do not write above this line)

State Well No. 9/1-16 del R  
State Permit No. G-4502

**(1) OWNER:**

Name Vernon Morgan - Bugabo Lumber Co  
Address RD. Box Mill City

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded   
12" Diam. from 0 ft. to 42 ft. Gage 25D  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used Oxy Acet.  
Size of perforations 1/8 in. by 8 in.  
84 perforations from 21 ft. to 42 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**

Static level 10'4 ft. below land surface Date 5-13-68  
Man pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " " "  
" " " " " "  
Bailer test 4.5 gal./min. with 26 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Cement  
Depth of seal 20' ft.  
Diameter of well bore to bottom of seal 20 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**

County Marion Driller's well number 294  
1/4 1/4 Section 15 T. 25 R. 1E W.M.  
Bearing and distance from section or subdivision corner

**(12) WELL LOG:**

Diameter of well below casing 8"  
Depth drilled 61 ft. Depth of completed well 61 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Soil	0	2	
Soil Med-Large Gravel	2	10	
Clay Med Gravel	10	20	
Med Gravel	20	24	14
Med Gravel - Large Boulders	24	41	10'4
Tuff Stone	41	61	10'4

Work started May 1 1968 Completed May 13 1968  
Date well drilling machine moved off of well May 13 1968

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] [Signature] Date May 13, 1968  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 117

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Long Drilling (Type or print)  
(Person, firm or corporation)

Address 4120 Fletcher Rd NE Salem, Oregon

[Signed] [Signature]  
(Water Well Contractor)

Contractor's License No. 75 Date May 13, 1968