WATER WELL REPORT STATE OF OREGON

MARI...... 15735

RECEIVED

JUL 2 0 1982 WATER RESOURCES DEPT. SALEM, OREGON

Ctata XXI-11 NT	95/10-17bc
State Well No.	1-10 120

State Permit No.	-

(1) OWNER:	(10) LOCATION OF WELL:
Name Camp Taloali	County Kartin Driller's well number 171,2
Address 1593), Hay #22	SW 14 NW 14 Section 17 T. 95 R. 17 W.M
City Stayton 97383 State Ore	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: Same
New Well ☑ Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 10 ft
	Static level 10 ft. below land surface. Date 7/9/82
Re Mud Dug Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date
C. Bored	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic	Depth drilled 62 ft. Depth of completed well 62 ft
6" Diam. from :0 ft. to62 ft. Gauge •250	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry
	for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED:	
	MATERIAL From To SWL
	Top soil 0' 1'
(6) PERFORATIONS: Perforated? ▼ Yes □ No	Large cobbles & sand (packed) 1' 13'
Type of perforator used Mills Knife	Cemented (cobbles & gravel) 13' 30'
Size of perforations in. by 2 in.	Cobbles & gravel (silted) 30' 40'
55 perforations from60 ft. to50 ft.	Cobbles & gravel (packed) 40' 56' 10
perforations from ft. to ft.	Gravel & sand 56' 58' 10*
perforations from ft. to ft. to ft.	Cemented gravel (orange) 58' 62' 10'
(7) SCREENS: Well screen installed? ☐ Yes 🙀 No	
Manufacturer's Name	
Type	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
pump test made? Yes No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
" " "	
Air test gal./min. with drill stem at ft. hrs.	
Bailer test 60 gal./min. with 20 ft. drawdown after 1 hrs.	
ian flow g.p.m.	
Temperature of water Depth artesian flow encountered ft.	Work started 7/2/82 19 Completed 7/9/82 19
(9) CONSTRUCTION: Special standards: Yes \(\subseteq \) No \(\subseteq \)	Date well drilling machine moved off of well 7/9/82 19
Well seal—Material usedCenent	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal 10 in.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	[Signed] (Drilling Machine Operator) Date 7/13/.82
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No. 320
How was cement grout placed?methodC	Woton Wall Control to 2 Courts
<u> </u>	Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to
Was pump installed?	the best of my knowledge and belief.
Was a drive shoe used? ★Yes No Plugs Size; location ft.	Name Pete Tolmasoff Well Drilling
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print) Address 7332 MacRobbins Lane SE, Turner 97392
Type of Water? depth of strata	
Method of sealing strata off	[Signed] (Water Well Contractor)
Was well gravel packed? ☐ Yes 🛣 No Size of gravel:	Contractor's License No. 410 Date 7/13/82
Gravel placed from ft. to ft.	19 19