

MARI... 15742

WATER WELL REPORT

STATE OF OREGON 6-4344

State Well No. 9/1-170

State Permit No.

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER: Name Maurice Sunderman Address 160 E. St. Stayton, Ore.

(2) LOCATION OF WELL: County Marion Owner's number, if any-- NE 1/4 NW 1/4 Section 17 T. 9S R. 1E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic [x] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ] (5) TYPE OF WELL: Rotary [ ] Cable [x] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(6) CASING INSTALLED: 8 5/8" Diam. from 0.6 ft. to 67 ft. Gage 250

(7) PERFORATIONS: Perforated? [ ] Yes [x] No Type of perforator used SIZE of perforations in. by in.

(8) SCREENS: Well screen installed [ ] Yes [x] No Manufacturer's Name Type Model No. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [ ] Yes [ ] No To what depth? ft. Material used in seal-- Did any strata contain unusable water? [ ] Yes [ ] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 14 ft. below land surface Date 6/30/60 Artesian pressure lbs. per square inch Date

Log Accepted by: Signed Maurice Sunderman Date June 29, 1960 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [ ] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 68 gal./min. with 8 ft. drawdown after 1 1/2 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(12) WELL LOG: Diameter of well 8 inches. Depth drilled 68 ft. Depth of completed well 68 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Entries include Large gravels & boulders with silt (0-18), Sand, coarse gravels to boulder size partly cemented with tan clay (18-51), Coarse gravels lightly cemented with clay and sand (51-68).

Work started 6/24/60 19 Completed 6/30/60 19

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Robinson Drilling & Supply (Person, firm, or corporation) Address 140 Pine St. NE Salem, Ore. Driller's well number [Signed] Harry G. Robinson (Well Driller) License No. 22 Date 7/1/60, 19