

MARION

15911

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 9/3-1771

State Permit No. 7 cd

(1) OWNER:

Name Bureau of Land Management Address 3550 Liberty Rd. S.E. P.O. Box 3227 Salem Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number 42963 NW 1/4 SW 1/4 Section 17 T. 9S R. 3E W.M. Bearing and distance from section or subdivision corner

Canyon Creek Recreation Site

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

6 5/8" Diam. from 0 ft. to 38 ft. Gage 250

(7) PERFORATIONS:

Perforated? [] Yes [x] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement Depth of seal 2.5 ft. Was a packer used? Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 21 ft. below land surface Date 5/10/63 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 14 gal./min. with 49 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 91 ft. Depth of completed well 90 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries: Silty Soil + gravel (0-2), Sand + gravel + Lenge (2-20), Boulders some clay (Brown) (20-30), Hard Rock (Basalt) (30-90), Tuff (30-90)

Work started 4/29 1963 Completed 5/10 1963 Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name Montgomery Ward Type: Hand Force H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George H. Robinson (person, firm or corporation) (Type or print)

Address 3965 Hayesville Dr. Salem

Drilling Machine Operator's License No. 64

[Signed] George H. Robinson (Water Well Contractor)

Contractor's License No. 17 Date 5/20 1963