

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED

WATER WELL REPORT

STATE OF OREGON (Please type or print)

MAR 1963 5983

State Well No. 9/4-28M

State Permit No.

(1) OWNER: Marion County Parks and Recreation Commission
 Name
 Address 1320 Edgewater Street
 Salem, Oregon

(2) LOCATION OF WELL:
 County Marion Driller's well number 62-12
 N.W. 1/4 S.W. 1/4 Section 28 T. 9 S R. 4 E W.M.
 Bearing and distance from section or subdivision corner
 110' N. - 520' E. of 1/16 Sec. Cor.
 1 P between Sec. 28 and 29

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

PROPOSED USE (check):
 Domestic Industrial Municipal Irrigation Test Well Other
 (5) TYPE OF WELL:
 Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:
 Threaded Welded
 6" Diam. from 0 ft. to 106 ft. Gage 280
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:
 Perforated? Yes No
 Type of perforator used
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(8) SCREENS:
 Well screen installed Yes No
 Manufacturer's Name
 Model No.
 Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: 1/4- crushed rock, drill-mud and cement grout.
 Well seal—Material used in seal
 Depth of seal 40 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 8 in. 10" to 23"
 Were any loose strata cemented off? Yes No Depth
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.
 Did any strata contain unusable water? Yes No
 Type of water Depth of strata
 Method of sealing strata off

(10) WATER LEVELS:
 Static level 86 ft. below land surface Date 7/11/62
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 " " " " "
 " " " " "
 Baller test 15 gal./min. with 24 ft. drawdown after 1 hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 5 7/8
 Depth drilled 128 ft. Depth of completed well 128 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Brown silty sand	0	5
Cemented sand and gravels to large cobble size - tan clay	5	96
Not quite so tightly cemented and with a red-brown clay	96	106
Very hard dark grey basalt rock - evidence of seams or crevices	106	128
Aquifer -		
Last twenty feet of gravel and seams in rock		

Work started 6/21 19 62 Completed 7/12 19 62
 Date well drilling machine moved off of well 7/12 19 62

(13) PUMP:
 Manufacturer's Name
 Type: H.P.

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME West Well Drilling (Person, firm or corporation) (Type or print)
 Address 4098 Market Street, N.E., Salem
 Drilling Machine Operator's License No.
 [Signed] Marion E. West (Water Well Contractor)
 Contractor's License No. 30 Date 7/12, 19 62