

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
MAY 21 1973
JUN 27 1973
STATE OF OREGON
STATE ENGINEER
SALEM OREGON
(Do not write above this line)

STATE ENGINEER, SALEM, OREGON 97301
within 30 days from the date
of well completion.

STATE OF OREGON
STATE ENGINEER
SALEM OREGON
(Please type or print)

16018

State Well No. 105/2W-4
State Permit No.

(1) OWNER:

Name WIZYER HARUSER CO
Address 7200 N WASHINGTON ST
98901

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10" Diam. from 1 ft. to 35 ft. Gage 2.50
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used TORCH
Size of perforations 3/8 in. by 6 in.
120 perforations from 19 ft. to 34 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? WIZYER
Yield: 600 gal./min. with 3/8 ft. drawdown after 4 hrs.
" " " "
" " " "
Ballor test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 4 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Washington Driller's well number
1/4 1/4 Section 4 T. 10 S. R. 2 W. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 10 ft.
Static level 10 ft. below land surface. Date 6-16-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled 35 ft. Depth of completed well 35 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
BROWN - SOIL	0	3	
CLAY & SAND GRAVEL	3	12	
BROWN - SAND & MED. GRAVEL	12	28	
TO LARGE BOULDER MED. SAND & GRAVEL WITH SOME CLAY	28	34	

Work started 6-13-1973 Completed 6-16-1973
Date well drilling machine moved off of well 6-16-1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Bill Jettens Date 6-19, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 651

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name WIZYER HARUSER
(Person, firm or corporation) (Type or print)
Address 5875 GAFFIN RD. S.E.
[Signed] Harusert
(Water Well Contractor)
Contractor's License No. 37 Date 6-19-1973