

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT AUG 10 1970 STATE ENGINEER SALEM, OREGON

STATE OF OREGON

(Please type or print)

write above this line)

State Well No. 10/2W-4

State Permit No.

(1) OWNER:

Name W.E. JERHARUSER CO. Address TACOMA WASH.

(2) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [x] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ]

CASING INSTALLED:

18" Diam. from 1 ft. to 33 ft. Gage 250

(6) PERFORATIONS:

Perforated? [ ] Yes [x] No.

Type of perforator used

Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 11 ft. below land surface Date 7-1-90

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [x] Yes [ ] No If yes, by whom? WEST

Yield: 2770 gal./min. with 13 ft. drawdown after 8 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? [ ] Yes [x] No

(10) CONSTRUCTION:

Well seal—Material used DRILL CUTTINGS + BENTONITE

Depth of seal 19 ft.

Diameter of well bore to bottom of seal 24 in.

Were any loose strata cemented off? [ ] Yes [x] No Depth

Was a drive shoe used? [x] Yes [ ] No

Did any strata contain unusable water? [ ] Yes [x] No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? [ ] Yes [x] No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MARION Driller's well number 1/4 1/4 Section 4 T. 10, S. R. 2, W W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 18

Depth drilled 50 ft. Depth of completed well 50 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Entries include: BROWN - UNCONSOLIDATED SAND + COARSE GRAVEL SOME SILT (0-24), BROWN - PARTLY CONSOLIDATED SAND + FINE GRAVEL SOME BROWN CLAY OCCASIONAL CEMENTED LAYERS (24-50), 17 FT. GALVANIZED SCREEN INSTALLED AT 3.3 FT. TO 50 FT.

Work started 6-16-1970 Completed 7-1-1970

Date well drilling machine moved off of well 7-3-1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Marion Curt Date 7-7-1970 (Drilling Machine Operator)

Drilling Machine Operator's License No. 188

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller & West (Person, firm or corporation) (Type or print)

Address 5545 Joseph St. S.E. SALEM

[Signed] Gordon R. Miller (Water Well Contractor)

Contractor's License No. 37 Date 7-7-1970