

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

MAR 10 1970

STATE ENGINEER, SALEM, OREGON 97330

within 30 days from the date of well completion.

AUG 1 0 1970

STATE OF OREGON

(Please type or print)

Do not write above this line

STATE ENGINEER SALEM, OREGON

State Well No. 10/2W-4

State Permit No.

(1) OWNER:

Name WESSER NAEUSER CO. Address TACOMA WASHINGTON

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [x] Cable [x] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

CASING INSTALLED:

1 1/2" Diam. from 1 ft. to 40 ft. Gage 250

PERFORATIONS:

Type of perforator used TORCH Perforated? [x] Yes [] No Size of perforations 7/8 in. by 6 in. 2 1/4 perforations from 22 ft. to 40 ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 11 ft. below land surface Date 5-26-70

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? WEST Yield: 1000 gal./min. with 11 ft. drawdown after 6 hrs.

(10) CONSTRUCTION:

Well seal-Material used DRILL CUTTINGS & BENTONITE Depth of seal 20 ft. Diameter of well bore to bottom of seal 20 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MARION Driller's well number 1/4 Section 4 T. 10, S. R. 2, W. W.M. Bearing and distance from section or subdivision corner

WELL NO. 2

(12) WELL LOG:

Diameter of well below casing 14 Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: BROWN - SANDY SILT (0-25), UNCONSOLIDATED (25-34), COARSE GRAVEL + SAND, BROWN - CEMENTED (34-38), SAND + GRAVEL, BROWN - UNCONSOLIDATED (38-40), ATED - SAND + GRAVEL.

Work started 5-1 - 1970 Completed 5-26 1970

Date well drilling machine moved off of well 6-15 - 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Mark West Date 6-8-1970 (Drilling Machine Operator)

Drilling Machine Operator's License No. 188

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller & West (Person, firm or corporation) (Type or print)

Address 5545 Joseph St. S.E. Salem

[Signed] Duane R. Miller (Water Well Contractor)

Contractor's License No. 37 Date 6-8-1970