

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

OCT 26 1972

State Well No.

53/1W-6ad

(Please type or print)

STATE ENGINEER

State Permit No.

(Do not write above this line)

SALEM, OREGON

G 6860

(1) OWNER:

Name Steve Coleman
Address Rt 1 Box 282
Perkasie Ore 97026

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
1.2" Diam. from 2 ft. to 157'4" ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used mills knife
Size of perforations 5/16 in. by 2 in.
480 perforations from 126 ft. to 142 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 650 gal./min. with 46 ft. drawdown after 4 hrs.
with air lift " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used clay & 2" pipe spudded in
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 12" in.
Diameter of well bore below seal 14 in.
Number of sacks of cement used in well seal _____ sacks
Number of sacks of bentonite used in well seal 6 Buckle sacks
Brand name of bentonite Garvid
Number of pounds of bentonite per 100 gallons of water 20 lbs./100 gals.
Was a drive shoe used? Yes No Plug _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 7215
1/4 1/4 Section 6 T. 55 R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 18' ft.
Static level 32'4" ft. below land surface. Date 10-20-72
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 159 ft. Depth of completed well 157' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	2	
brown clay	2	18	
blue silt clay	18	67	
blue clay	67	80	
black sand	80	82	35'
gray clay	82	90	
black sand	90	97	
gray clay	97	102	
black sand & clay layers	102	118	
black sand & gravel	118	141	35'
blue clay	141	159	

Work started 9-7 1972 Completed 10-20 1972
Date well drilling machine moved off of well 10-20 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Edgar J. Muller Date 10-24, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 581

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Milo Schneider Exp. Co.
(Person, firm or corporation) (Type or print)

Address Stay Rt, Box 97 St Paul Ore 97137

[Signed] Milo Schneider
(Water Well Contractor)

Contractor's License No. 387 Date 10-24, 1972