WATER WELL REPORT
STATE OF OREGON

MARI.....
16126

RECEIVED
APR 24 1987
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 10S/3W-1

State Permit No. .....

PLEASE TYPE or PRINT IN INK

(1) OWNER:

Name M.L. McDONALD
Address 3393 JEFFERSON-MARION RD. SE
City JEFFERSON OR. State

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☐ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☒ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:

Steel ☒ Plastic ☐
Threaded ☐ Welded ☒

6" Diam. from +1 ft. to 27 ft. Gauge 250
..." Diam. from ..... ft. to ..... ft. Gauge .....

LINER INSTALLED:

..." Diam. from ..... ft. to ..... ft. Gauge .....

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No
Manufacturer's Name .....
Type ..... Model No. .....
Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.
Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test 14 gal./min. with 25 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ..... ft.

(9) CONSTRUCTION:

Special standards: Yes ☐ No ☒
Well seal—Material used CEMENT
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? TREMIE

Was pump installed? ..... Type ..... HP ..... Depth ..... ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs ..... Size: location ..... ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

(10) LOCATION OF WELL:

County MARION Driller's well number
¼ ¼ Section 1 T. 10S R. 3W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location:

(11) WATER LEVEL: Completed well.

Depth at which water was first found 10 ft.
Static level 5 ft. below land surface. Date 2-4-87
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 50 ft. Depth of completed well 50 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
CONGLOMARENT (MED)	1	10	
GRAVEL (MED)	10	22	
CLAYSTONE (BLUE)	22	50	

Work started 1-30 1987 Completed 2-4 1987
Date well drilling machine moved off of well 2-5 1987

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] W.A. Pancheller Date 3-15, 1987

Bonded Water Well Constructor Certification:

Bond ..... (number) Issued by: ..... Surety Company Name

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name BUD'S WELL DRILLING (Person, firm or corporation) (Type or print)
Address 1257 N.E. CLOVER RIDGE RD. ALBANY, OREGON 97321
[Signed] W.A. Pancheller Water Well Constructor
LIC 621 Date 3-15, 1987

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*45292-690