

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 1 1964 STATE ENGINEER SALEM, OREGON

MARI... 16/82

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

State Well No. 10/3w-2

State Permit No.

(1) OWNER:

Name N. W. Combatley  
Address P O Box 11, Talbot Road  
Jefferson, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number 64-11  
1/4 1/4 Section 2 T. 10 S R. 3 W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
8" Diam. from 0 ft. to 51 ft. Gage .250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Cutting torch  
Size of perforations 5/16 in. by 6 in.  
45 perforations from 34 ft. to 53 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Drill mud  
Depth of seal 18 ft. Was a packer used? NO  
Diameter of well bore to bottom of seal 11 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusuable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 25 ft. below land surface Date 5-18-64  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Bailer test 40 gal./min. with 8 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 8" +  
Depth drilled 57 ft. Depth of completed well 55 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Gravelly brown topsoil	0	2
Coarse unconsolidated gravels to cobble size - much silty clay and brown sand	2	32
Small gravel and brown sand - not cemented but with much muddy silt in water	32	53
Blue clay - caving	53	57

Work started 5-12 1964. Completed 5-18 1964  
Date well drilling machine moved off of well 5-18 1964

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME West Well Drilling (Person, firm or corporation) (Type or print)  
Address 4098 Market Street, N. E., Salem, Oregon

Drilling Machine Operator's License No. 188

[Signed] Marion E. West (Water Well Contractor)

Contractor's License No. 30 Date 5-21, 1964