

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON JUN 6 1975

(Please type or print) STATE ENGINEER

(Do not write above this line) SALEM, OREGON

State Well No. 105/3W-12-AC

State Permit No.

(1) OWNER:

Name Charles G. Hart Jr. (Troy)
Address Rt. 1, Box # 321
Jefferson, Oregon 97352

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

6" Diam. from 0 ft. to 33 ft. Gage 250
Threaded Welded

PERFORATIONS:

Type of perforator used ~~XXXX~~ torch Perforated? Yes No
Size of perforations 1/8 in. by 6 in.
36 perforations from 24 ft. to 31 ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 75 gal./min. with 12 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in. 8
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 62575J
NE 1/4 SW 1/4 Section 12 T. 10S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 22 ft.
Static level 12 ft. below land surface. Date 5-29-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 45 ft. Depth of completed well 45 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	1	
brown clay	1	10	
brown clay & gravel	10	17	
XXXX brown sand	17	21	
medium gravel & sand	21	31	12'
blue clay	31	37	
blue silty clay	37	43	
brown sand	43	45	

Work started 5-28 19 75 Completed 5-29 1975
Date well drilling machine moved off of well 5-29 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] _____ Date 6/2 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. 829

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Schoen Electric & Pump
(Person, firm or corporation) (Type or print)
Address 226 W. Queen Ave. - Albany, Or. 97321
[Signed] _____
(Water Well Contractor)
Contractor's License No. 513 Date 6/4 1975