

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
WATER WELL REPORT
JUL 24 1967
STATE OF OREGON
STATE ENGINEER
SALEM, OREGON

1626
MARI...
G-4050

State Well No. 5/1w-7J

State Permit No. _____

(1) OWNER:

Name St. Luke's Cemetery Assoc., Inc.
Address 782 N. Third St. Woodburn, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
8" Diam. from top ft. to 130 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills
Size of perforations 3/8 in. by 2 in.
64 perforations from 119 ft. to 124 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 40 ft. below land surface Date 7/18/67
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? driller
Yield: 100 gal./min. with 70 ft. drawdown after 4 hrs.
80 " " 55 " " 4 "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 54 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Drill cuttings & Puddle clay
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 1237
1/4 Section 7 T. 5S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 130 ft. Depth of completed well 130 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil	0	3	
Yellow Clay	3	18	
Gray sandy shale	18	35	
Silty yellow clay	18	35	
Gray sandy shale	35	60	40
Black sandy shale	60	75	
Black sand	75	80	
Black sand shale	80	100	
Greenish black shale			
Black sand	100	113	
Black sand small gravel	113	114	
Greenish black shale	114	116	
Black sand & small gravel	116	123	
Black sand & mud	123	130	
Brown sandy shale	130		40

Work started 7/7/67 19 Completed 7/18/67 19
Date well drilling machine moved off of well 7/18/67 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] James H. ... Date 7/18/67 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 74

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY
(Person, firm or corporation) (Type or print)

Address Rt. 2 Box 276, Salem, Oregon

[Signed] Emil J. Beier
(Water Well Contractor)

Contractor's License No. 2 Date 7/18/67 19