STATE ENGINEER Salem, Oregon Well Record	APPLICATION NO. GR- 160
OWNER: Harry M. Wall ADDRE	ND
LOCATION OF WELL: Owner's No. 1 STATE:	
NW 1/4 NW 1/4 Sec. 13 T. 10 S., R. 3 W., W.M.	D(1)
Bearing and distance from section or subdivision	<del>σ</del>
corner 34.27 ch. E. of NW cor. of the T. Holt	
DLC #67, then S $7\frac{1}{2}$ ch. + 1 rod to well.	
Altitude at well 227!	
TYPE OF WELL: Drilled Date Constructed Sept. 1946  Depth drilled 25' Depth cased 25'	Section 13
Depth drilled Depth cased	
CASING RECORD: 8 inch FINISH:  1/2" perforations from 11 to 25 feet	
A OTTTERDIC.	
AQUIFERS:  River gravel from ? to 25 feet	
WATER LEVEL: 10 feet	
PUMPING EQUIPMENT: Type F. M. 3 phase Capacity 130 G.P.M.	H.P. 7불
WELL TESTS:  Drawdown 5 ft. after hours	130 G.P.M.
Drawdown ft. after hours	G.P.M.
Drawdown 16. arter	

REMARKS: 0 to ? Top soil ?????? Soil, sandy ? to 25 Gravel, river

ADDITIONAL DATA:

USE OF WATER Irrigation (6 acres) Temp. °F. ,19.

SOURCE OF INFORMATION GR- 153

DRILLER or DIGGER Marion West, Salem

Log X Water Level Measurements ...... Chemical Analysis ............ Aquifer Test ......