

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

MARI 1642 RECEIVED

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

AUG 15 1974

State Well No.

5S/1W-8da

STATE ENGINEER
SALEM, OREGON

State Permit No.

G6354

app 6 6770

(1) OWNER:

Name CITY OF WOODBURN
Address 550 N. 1ST ST. WOODBURN, ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
16" Diam. from 72 ft. to 122 ft. Gage 312
14" Diam. from 119 ft. to 123 ft. Gage 250
14" Diam. from 139 ft. to 179 ft. Gage 250
14" Diam. from 184 ft. to 194 ft. Gage 250

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name WOP JOHNSON
Type STAINLESS STEEL Model No. _____
Diam. 16 Slot size 100 Set from 123 ft. to 139 ft.
Diam. 16 Slot size 100 Set from 179 ft. to 189 ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 868 gal./min. with 59.6 ft. drawdown after 24 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water 55° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT
Well sealed from land surface to 6.0 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal 16 in.
Number of sacks of cement used in well seal 129 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County MARION Driller's well number 5483
NE 1/4 SE 1/4 Section 8 T. 5S R. 1W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 123 ft.
Static level 51.5 ft. below land surface. Date 8/1/74
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 194 ft. Depth of completed well 194 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	2	
TAN SILT	2	37	
GREY SILT	37	74	
FINE GREY SILTY SAND	74	91	
BLUE GREEN CLAY	91	94	
STICKY GREY CLAY	94	101	
TAN AND GREY SILTY SAND	101	109	
GREY SILT	109	113	
DARK GREY FINE SAND	113	118	
DIRTY SAND, SOME GRAVEL	118	123	
LOOSE SAND AND GRAVEL	123	138	
GREY AND BLUE CLAY	138	142	
GREY AND GREEN CLAY	142	151	
GREY SANDY SILT	151	163	
SAND, SILT, GRAVEL	163	178	
LOOSE SAND AND GRAVEL	178	189	
GREY AND GREEN CLAY	189	194	

Work started JUNE 12 1974 Completed AUG 8, 1974

Date well drilling machine moved off of well AUG 8 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Allen Rydman Date AUG 14 1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 54

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name R. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LANE POPP AND ORE.

[Signed] Robert J. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date AUG 13, 1974



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301
(503) 986-0900
www.wrd.state.or.us

Application for
Well ID Number

Do not complete if the well already has a Well I.D Number.

I OWNER INFORMATION

Current Owner Name (please print): City of Woodburn, OR.
Mailing Address: 270 Montgomery St.
City: Woodburn State: OR. Zip: 97071
Mailing Address (to send Well I.D.): "Above"
City: State: Zip:

II WELL INFORMATION (Do not complete this section if the well report is attached.)

Township: 5S (North/South) Range: 1W (East/West) Section: 8
Tax Lot: 2900 County: Marion NE 1/4 SW 1/4
Street Address of Well: 1750 Alexandria Ave - Legion Park City: Woodburn
Owner at time the well was constructed, (if known):
If the property had a different street address in the past:

III GENERAL WELL INFORMATION (Do not complete this section if the well report is attached)

Use of Well (domestic, irrigation, commercial, industrial, monitoring):
Date Well Constructed: Total Well Depth: Casing Diameter:
Other Information: "well #8"

SUBMITTED BY (please print): Dennis R. Samson
PHONE: 503-982-5380 FAX: 982-7846

Send application to Oregon Water Resources Department; 725 Summer St NE, Suite A; Salem, Oregon 97301-1266; fax (503) 986-0902. Applications are processed and Well I.D. Numbers are mailed every Wednesday.

For Official Use Only by the Oregon Water Resources Department:
Received Date: 12-11-08 Well Log Number: MARI 1642 Well Identification #: L-99854

RECEIVED

Last Update: 11/04/08

Well I.D. Number/ 1

DEC 11 2008

WCC

* Revised to add tax lot, QQ, etc. per Groundwater site est. 2001

WATER RESOURCES DEPT SALEM, OREGON