

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

AUG 21 1975 (Please type or print)

(Do not write above this line)

WATER RESOURCES DEPT.

MA. R.I. 16492

State Well No. 75/2W-38

State Permit No.

See 6-9320 3Acre.

(1) OWNER: SALEM, OREGON

Name Russ Pease Address 4860 Pennsylvania S.E., Salem

(2) TYPE OF WORK (check): New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored [] Domestic [X] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

CASING INSTALLED: 6" Diam. from 0 ft. to 9.5 ft. Gage 250

PERFORATIONS: Perforated? [] Yes [X] No.

Type of perforator used Size of perforations in. by in.

(7) SCREENS: Well screen installed? [] Yes [X] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

Baller test 37 gal./min. with 10 ft. drawdown after 1 hrs.

Artesian flow g.p.m. erature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal-Material used Bentonite Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal sacks Number of sacks of bentonite used in well seal 2 sacks

Brand name of bentonite National Number of pounds of bentonite per 100 gallons of water 30 lbs./100 gals.

Was a drive shoe used? [X] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [X] No

Type of water? depth of strata Method of sealing strata off

Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion 33 Driller's well number 1/4 1/4 Section 28 T. 75 R. 2 W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 25 ft. Static level 42 ft. below land surface. Date 7-14-75

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing

Depth drilled 95 ft. Depth of completed well 95 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Top soil, Brown clay, Sand & gravel, Cemented gravel & sand, Gravel & sand.

Work started 7-8 1975 Completed 7-14 1975

Date well drilling machine moved off of well 7-14 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Paul J. Peterson Date 7-15, 1975 (Drilling Machine Operator)

Drilling Machine Operator's License No. 549

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Robinson Eola Drilling (Person, firm or corporation) (Type or print)

Address 4570 Dallas-Salem Hwy [Signed] George H. Robinson (Water Well Contractor)

Contractor's License No. 13 Date 8-19, 1975