

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
OCT - 3 1963
STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

1656
5S/1W-81
MARI...56
G 2739

State Well No. _____
State Permit No. _____

(1) OWNER:

Name Albert Lenners
Address Woodburn, Oregon

(2) LOCATION OF WELL:

County Marian Driller's well number _____
1/4 Section 8 T. 5S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 117 ft. Gage 1/4"
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from _____ ft. to _____ ft.
Diam. Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Mud
Depth of seal 25 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 41 ft. below land surface Date 9/4/63
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? driller
Yield: 100 gal./min. with 94 ft. drawdown after 8 hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 125 ft. Depth of completed well 125 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface	0	3
Brown sandy clay	3	37
Sandy blue clay	37	67
Blue clay	67	78
Black sand	78	81
Small gravel & Coarse sand	81	85
Blue clay	85	93
Black sand (broken)	93	97
Clay	97	105
Gravel	105	106
Broken clay and sand	106	117
Gravel	117	125

Work started Aug 31 1963. Completed Sept 4 1963
Date well drilling machine moved off of well Sept 5 1963

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller
(Person, firm or corporation) (Type or print)

Address P O Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 277 26

[Signed] John T. Miller
(Water Well Contractor)

Contractor's License No. 26 Date Sept 25, 1963