RECEIVED FEB 8 1961

MARI...

167566 7/3W 1P

MARI

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

← Notice

WATER WELL REPORT
STATE OF OREGON

State Well No. .....

State Permit No. .....

(1) OWNER:

Name W.J. Murphy

Address 2190 Kapphahn Rd. NE
Salem, Ore.

(2) LOCATION OF WELL:

County Marion Owner's number, if any—

¼ ¼ Section T. R. W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒

6 5/8" Diam. from 1½ ft. to 44½ ft. Gage .250

..... " Diam. from ..... ft. to ..... ft. Gage .....

..... " Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS: Perforated? ☐ Yes ☒ No

Type of perforator used

SIZE of perforations in. by in.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

(8) SCREENS: Well screen installed ☐ Yes ☒ No

Manufacturer's Name .....

Type ..... Model No. .....

Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:

Was well gravel packed? ☐ Yes ☒ No Size of gravel: .....

Gravel placed from ..... ft. to ..... ft.

Was a surface seal provided? ☒ Yes ☐ No To what depth? ..... ft.

Material used in seal— Drillings

Did any strata contain unusable water? ☐ Yes ☐ No

Type of water? Depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 16 ft. below land surface Date 12/6/60

Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] ..... (Owner) Date ....., 19.....

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 40 gal./min. with 6 ft. drawdown after 1½ hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG: Diameter of well 6 inches.

Depth drilled 44½ ft. Depth of completed well 44½ ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top soil	0	1½
Brown sandy clay	1½	25
Loose fine gravel & sand	25	35
Coarse gravel with sand & some brown clay (aquifer)	35	44½

Work started 12/5/60 19 . Completed 12/6/60 19

(13) PUMP:

Manufacturer's Name .....

Type: ..... H.P. .....

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Robinson Drilling & Supply (Person, firm, or corporation) (Type or print)

Address 140 Pine St N Salem, Ore.

Driller's well number 7/3W-1P1

[Signed] Harry G. Robinson (Well Driller)

License No. 22 Date 12/22/60, 19.....

(USE ADDITIONAL SHEETS IF NECESSARY)