

RECEIVED

MARI. ~~10806~~

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON, within 30 days from the date of well completion.

AUG 20 1962 WATER WELL REPORT

STATE ENGINEER SALEM, OREGON (Please type or print)

10806

State Well No.

State Permit No.

7/3W-2

(1) OWNER:

Name OTIS A. ANDERSON
Address 5125 VERDA LANE N.E. SALEM, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number 770
Bearing and distance from section or subdivision corner Lot 18 T. 7 S R 3 WW, M

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 50 ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used Milles
Size of perforations in. by in.
120 perforations from 34 ft. to 49 ft.

(8) SCREENS:

Well screen installed [] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddle clay
Depth of seal 18 ft. Was a packer used?
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 8 ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom? driller
Yield: 270 gal./min. with 10 ft. drawdown after 5 hrs.
" 370 " " 12 " 5 "
" 400 " " 15 " 5 "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 50 ft. Depth of completed well 50 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows: TOP SOIL (0-5), SANDY SILT & GRAVEL (5-14), SAND GRAVEL & WATER (14-50)

Work started AUG. 16 1962. Completed AUG 23 1962
Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO
Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 141

[Signed] Emil O. Beier (Water Well Contractor)

Contractor's License No. 2 Date AUG. 23 1962