

16829
MARI.

WATER WELL DRILLERS REPORT
STATE OF OREGON

Do Not State Well No. 9/3W-2 D (1)
Fill In State Permit No. M

(1) OWNER:

Name The First National Bank of Portland
Address P. O. Box 3457
Portland, Oregon

(2) LOCATION OF WELL:

County Marion Owner's number, if any--
R. F. D. or Street No. 4605 N. River Road, Salem, Oregon
Bearing and distance from section or subdivision corner
400 ft North and 50 feet west NW corner
TNO. Force DLG. In Section 2, T7S,
R3W.

(3) TYPE OF WORK (check):

New well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) EQUIPMENT:

Rotary
Cable
Dug Well

(6) CASING INSTALLED:

FROM	ft. to	ft.	Diam.	Gage or Wall	If gravel packed	Diameter of Bore	from	to
							ft.	ft.
" 1 "	" 121 "	" 8 "	" 4 "	" "				
" "	" "	" "	" "	" "	NONE	" "	" "	" "
" "	" "	" "	" "	" "				
" "	" "	" "	" "	" "				
" "	" "	" "	" "	" "				

Type and size of shoe or well ring, STEEL
Describe joint WELDED

(7) PERFORATIONS:

FROM	ft. to	ft.	Type of perforator used	Size of perforations	in. length, by	per per foot	No. of rows
" 105 "	" 115 "	" 8 "	MILLS TYPE	3/4	2 1/2	16	" "
" "	" "	" "	" "	" "	" "	" "	" "
" "	" "	" "	" "	" "	" "	" "	" "
" "	" "	" "	" "	" "	" "	" "	" "
" "	" "	" "	" "	" "	" "	" "	" "

SCREENS:

Give Manufacturer's Name, Model No. and Size NONE

(8) CONSTRUCTION:

Was a surface sanitary seal provided? Yes No To what depth 6" ft.
Were any strata sealed against pollution? Yes No
If yes, note depth of strata
FROM 1' ft. to 104' ft.
METHOD OF SEALING BACK FILL + TAMPING

(9) WATER LEVELS:

Depth at which water was first found 105' ft.
Standing level before perforating 15' ft.
Standing level after perforating 15' ft.
Log Accepted by [Signature] of Portland
[Signed] First Nat'l Bank Dated May 15, 19 57
BY: [Signature] Assistant Vice President

(10) WELL TESTS:

Was a pump test made? Yes No If yes, by whom? STETTLER SUPPLY
Yield: 300 gal./min. with 31 ft. draw down after 4 hrs.
" 175 " 13'6" " 15 MI
" 125 " 0 " 15 MI
Artesian flow _____ g.p.m.
Shut-in pressure _____ lbs. per square inch.
Bailer test _____ g.p.m. with _____ ft. drawdown
Temperature of water 54° Was a chemical analysis made? Yes No
Was electric log made of well? Yes No

(11) WELL LOG:

Diameter of well, 8" 1-0 inches.
Total depth 121' ft. Depth of completed well 121' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.
ft. to ft.
3' " 3' " TOP SOIL
7' " 10' " SANDY CLAY YELLOW COLOR
5' " 15' " SAND - 15% CLAY
19' " 34' " CEMENTED GRAVEL YELLOW
1' " 35' " WATER GRAVEL #4 -
22' " 57' " CEMENTED GRAVEL
1' " 58' " WATER GRAVEL # 2 -
22' " 80' " CEMENTED GRAVEL # 10 -
14' " 94' " BLUE CLAY
4' " 98' " DECOMPOSED VEGETATION
5' " 104' " CEMENTED GRAVEL
17' " 121' " WATER GRAVEL

Ground elevation at well site _____ feet above mean sea level.
Work started 4-29 1957 Completed 5-4- 19 57

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED + SONS

(Person, firm, or corporation) (Typed or printed)

Address 2505 BROOKS ST. SALEM ORE.

Driller's well number

[Signed] [Signature] (Well Driller)
License No. 6 Dated 5-8- 19 57

STATE ENGINEER
Salem, Oregon

State Well No. 7/3W-2 M(1)

County Marion

Application No. G.936

Water Level Record

OWNER: THE FIRST NAT'L BANK OF PORTLAND OWNER'S NO. _____

Description of measuring point: Top of casing, 20 below L.S.D

Date	Water Level Feet (above) (below) Land Surface	Remarks ^{8"}	Date	Water Level Feet (above) (below) Land Surface	Remarks
6-23-58	15.8	Final Proof Survey			

REMARKS: _____
