

#2-62

RECEIVED MARI. ~~1962~~
MAR 15 1962 WATER WELL REPORT
STATE ENGINEER STATE OF OREGON

16815
MAR 15 1962

7/3W-4G

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

State Well No. _____
State Permit No. _____

(1) OWNER:
Name John Charge
Address Rt. 1, Box 394 Salem Ore

(2) LOCATION OF WELL:
County Marion Owner's number, if any—
S.W. 1/4 N.E. 1/4 Section 4 T. 7 S. R. 3 W. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
" Diam. from _____ ft. to _____ ft. Gage _____
6 " Diam. from +1 1/2 ft. to 6.5 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used _____
SIZE of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
_____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal— DRAINING CLAY
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 27 ft. below land surface Date 3/7/62
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:
[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test 35 gal./min. with 16 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 4 inches.
Depth drilled 62 ft. Depth of completed well 62 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil - Silt	0	7
Brown Clay	7	24
SANDY CLAY & MEDIUM BROWN	24	34
COARSE GRAVEL & BROWN CLAY	34	60
11 SAND & FINE GRAVEL	60	62

Work started 2/23/62 Completed 3/5/62

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME George H. Robinson
(Person, firm, or corporation) (Type or print)
Address 3965 Hayesville Dr
Driller's well number 3-562
[Signed] George H. Robinson
(Well Driller)
License No. 335 Date 3/6, 1962