

#1-58 1/2

RECEIVED
MAR 15 1962

MARI

WATER WELL REPORT

16876
MARI

7/3W-4H

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER

STATE OF OREGON

State Well No.

State Permit No.

(1) OWNER:

Name Reuben Charge
Address Rt. 1, Box 388 Salem Ore.

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
S.E. 1/4 NE, 1/4 Section 4 T. 7 S R. 3 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

6" Diam. from _____ ft. to _____ ft. Gage _____
4" Diam. from 71 ft. to 58 1/2 ft. Gage 1280
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
SIZE of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal— DALLING CLAY
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 29 ft. below land surface Date 3/7/62
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? -
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test 40 gal./min. with 9 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.

Depth drilled 58 1/2 ft. Depth of completed well 58 1/2 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|-------------------------------|------|--------|
| Top Soil - SILT | 0 | 7 |
| BROWN CLAY | 7 | 26 |
| SANDY CLAY & MEDIUM SAND | 26 | 35 |
| COARSE GRAVEL WITH BROWN CLAY | 35 | 56 |
| " SAND & FINE GRAVEL | 56 | 58 1/2 |

Work started 2/14/62 19____ Completed 2/22/62 19____

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George Robinson
(Person, firm, or corporation) (Type or print)

Address 3965 Hayesville Dr.

Driller's well number 2-2262

[Signed] George H. Robinson
(Well Driller)

License No. 335 Date 2/23/62, 19____