

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date
of well completion

STATE OF OREGON

(Please type or print)

State Well No.

State Permit No.

Do not write above this line)

(1) OWNER:

Name Paul Park STATE ENGINEER
Address 4205 Turner Road SALEM OREGON

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☒ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 6.5 ft. Gage 2.50
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Baller test 50 gal./min. with 35 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water 55 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite
Well sealed from land surface to 6.5 ft.
Diameter of well bore to bottom of seal 6 in.
Diameter of well bore below seal in.
Number of sacks of cement used in well seal 8 sacks
Number of sacks of bentonite used in well seal 5 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water 50 lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number
SE 1/4 SW 1/4 Section 7 T. 7S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 30 ft.
Static level 5 ft. below land surface. Date Oct. 25, 71
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing

Depth drilled 66 ft. Depth of completed well 65 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	2	
Clay - Brown	3	6	
Clay - Brown + Gravel	5	12	
Sand + Gravel	13	42	
Cemented Gravel	43	46	
Sand + Gravel Loose	47	65	5

Work started Oct. 20 19 71 Completed Oct. 25 19 71Date well drilling machine moved off of well Oct. 26 19 71

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Robert J. Mason Date Oct. 25, 1971
(Drilling Machine Operator)

Drilling Machine Operator's License No. 760

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Duffield Bros. Water Wells, Inc.
(Person, firm or corporation) (Type or print)

Address 1002 Dianne Dr. SE, Salem, Ore.

[Signed] Robert P. Eiler
(Water Well Contractor)

Contractor's License No. 551 Date 10/27, 1971