

Received 9/7/56
3 PM

App G 544

(1) OWNER:

Name MARC SAUCY
Address 2355 CLAXTER ROAD
SALEM ORE.

(2) LOCATION OF WELL:

County MARION Owner's number, if any—
R. F. D. or Street No.
Bearing and distance from section or subdivision corner
300ft East & 500 feet South from NW
corner of section 12. Being in the NW 1/4 of
the NE 1/4 of Section 12. T7S, R3W

TYPE OF WORK (check):

New well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) EQUIPMENT:

Rotary
Cable
Dug Well

(6) CASING INSTALLED:

Threaded Welded

FROM	ft. to	ft.	Diam.	Gage or Wall	Diameter of Bore	from ft.	to ft.
"	1'	80'	6"	1/4"			
"	"	"	"	"	NONE	"	"
"	"	"	"	"	"	"	"
"	"	"	"	"	"	"	"
"	"	"	"	"	"	"	"

If gravel packed

Type and size of shoe or well ring 6" steel Size of gravel:
Describe joint WELDED

(7) PERFORATIONS:

Type of perforator used MILLS TYPE

SIZE of perforations	ft.	ft.	in., length, by	in.	No. of rows
FROM	ft. to	ft.	perf per foot		
"	60'	80'	6"	1/8"	18
"	"	"	"	"	"
"	"	"	"	"	"
"	"	"	"	"	"

SCREENS:

Give Manufacturer's Name, Model No. and Size NONE

(8) CONSTRUCTION:

Was a surface sanitary seal provided? Yes No To what depth 6" ft.

Were any strata sealed against pollution? Yes No

If yes, note depth of strata

FROM 1' ft. to 60' ft.

METHOD OF SEALING BACK FILL

(9) WATER LEVELS:

Depth at which water was first found 60' ft.

Standing level before perforating 40' ft.

Standing level after perforating 40' ft.

Log Accepted by:

[Signed] Marc Saucy dated 9/7, 1956
Owner

(10) WELL TESTS:

Was a pump test made? Yes No If yes, by whom? STETTLER SUPPLY
Yield: 360 gal./min. with 30' ft. draw down after 1/2 hrs.
" 250 " " 17 1/2 " " 1/2 "
" 225 " " 12 " " 1/2 "
Artesian flow _____ g.p.m.
Shut-in pressure _____ lbs. per square inch.
Baller test _____ g.p.m. with _____ ft. drawdown
Temperature of water 58° Was a chemical analysis made? Yes No
Was electric log made of well? Yes No

(11) WELL LOG:

Diameter of well, 6" 1-P inches.
Total depth 80' ft. Depth of completed well 80' ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

ft. to	ft.	
1'6"	1'6"	TOPSOIL
12'6"	14'	YELLOW CLAY
27	41	YELLOW SILT
45	45'	CEMENT GRAVEL YELLOW
10'	55'	FINE SAND + GRAVEL
5'	60'	CEMENT GRAVEL
4'	64'	WATER GRAVEL 40 G.P.M.
12'	76'	CEMENT GRAVEL WATER B.
4'	80'	WATER GRAVEL # 7-

TO "APPLY for Irrigation Permit.

Ground elevation at well site 175 feet above mean sea level.

Work started 8-27 1956 Completed 8-28-1956

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS
(Person, firm, or corporation) (Typed or printed)

Address 2505 BROOKS ST SALEM ORE

Driller's well number

[Signed] J.A. Sneed
(Well Driller)

License No. 6 Dated 8 30, 1956