NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 9/310 within 30 days from the date of well completion.

WATER WELL REPORT C IVED

STATE OF OREGON

(Please type or print)

(Do not write above this line) ER RESOURCES DEPT.

State Permit No. 55/100-9

(1) OWNER:	(10) LOCATION OF WELL:
Name Yakov Kuznetson	County Marion Driller's well number
Address RI Box 284	NE 45W4 Section 9 T. 5.3 R. / (1) W.M.
woodburn on	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well 📥 Deepening 🗌 Reconditioning 🗎 Abandon 🗌	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	
Rotary Driven Domestic Productical Definition D	Depth at which water was first found 76 ft.
Cable	Static level /8 ft. below land surface. Date 5-11-76
	Artesian pressure Ibs. per square inch. Date
CASING INSTALLED: Threaded □ Welded □	(12) WELL LOG: Diameter of well below casing
6 " Diam. from 0 ft. to 120 ft. Gage 250	Donth drilled /2 / St. Donth of sound to de la constant de la cons
" Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
PERFORATIONS: Perforated? [] Ves [] Ves	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
FERFORATIONS: Perforated? Yes 76.	
	MATERIAL From To SWL
- A-1	70/P Soll 0 2 Brown C/24 2 38
perforations fromft. toft.	10000
perforations fromft. toft. perforations fromft. toft.	13/4 e C. (ay 38 76 Fine Black Sind 76 94 18
	Blue Clay 94 106
(7) SCREENS: Well screen installed? Yes No	Black sand & gravel 106 114 18
Manufacturer's Name	Loss gravel 11412018
TypeModel No.	
Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Exes I No If yes, by whom? Daller	*
Yield: 70 gal./min. with 20 tt. drawdown after 5 hrs.	
" " "	
n n n n	
Bailer test gal./min. with ft. drawdown after hrs.	10 1 10 10 10 10 10 10 10 10 10 10 10 10
Artesian flow g.p.m. Tt. drawdown after hrs.	
Ton Stone	
perature of water Depth artesian now encountered	Work started 5 - 7 1976 Completed 5 - 11 1976
(9) CONSTRUCTION:	Date well drilling machine moved off of well $5-12$ 1976
Well seal-Material used Coment	Drilling Machine Operator's Certification:
Well sealed from land surface to 28 ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal 11 in.	best knowledge and belief.
Diameter of well bore below seal in.	[Signed] Jakn W Ugack Date 5-12 1976
Number of sacks of cement used in will seal sacks	(Drilling Machine Operator) Drilling Machine Operator's License No. 437
Number of sacks of bentonite used in well sal sacks	Special Special B Linceline 140.
Brand name of bentonite Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:
of water Ibs./100 gals,	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? 🖟 Tes 🗌 No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water? 🎵 🤁 🔲 No	Name Jw Beck Welldrilling (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 24137 8 SKylane Pr Conty Ore
Method of sealing strata off	100
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	[Signed] Water Well Contractor)
Gravel placed fromft_toft.	Contractor's License No. 449 Date 5-12 19 76
/TOP AND	19.6