STATE ENGINEER Salem, Oregon



STATE WELL NO. 7/3W-14F..... COUNTY Marion APPLICATION NO. GR- 1482

and the same of th				
OWNER: M.B. Clatterbuck, Supt. Oregon	MAILING ADDRESS:			
School for the deaf.				# # # # # # # # # # # # # # # # # # #
LOCATION OF WELL: Owner's No. #2.		alem. Orego	<u>n</u>	
SE_4NW4 Sec. 14_ T7 S., R3 W.,	337 N/I	1	. !	1
	AA *1AT*	i	Ì	
Bearing and distance from section or subdivision				
corner 3340' W. & 1350' S. from NE cor. Sec.	14.	** 5	İ	
		WELL		
	-		•	1
				-
Altitude at well				
TYPE OF WELL: Drilled Date Constructed 19	50	•]
Depth drilled1531 Depth cased1531	*********	Section	14	
CASING RECORD:				
10"				
±0				
FINISH:				
Perforated casing every 3t to bottom of we	17.			
19110191000 Georgie Chord D. 101 101				
AQUIFERS:				
WATER LEVEL:				
20 ¹				
TI turking			TTD	, 30
PUMPING EQUIPMENT: Type 5" turbine Capacity)W
WELL TESTS: Drawdown ft. after	houng			C D M
Drawdown ft. after	hours			G.P.M.
USE OF WATER Dom. & Irrigation	Temp °F	7		, 19
SOURCE OF INFORMATION GR Record				
DRILLER or DIGGER R. Stadeli & Sons				
ADDITIONAL DATA: LogX Water Level Measurements	Chemical Anal	vsis	Aquifer Test	
	. Chemical Allai	y 515	. riquitet i est	
REMARKS:				

Irrigation of 50 acres.

STATE ENGINEER Salem, Oregon

State Well No. 7/3W-14F				
County Marion				
Application No. GR- 1482				

Well Log

ller: R. Stadeli & Sons	Date Drilled1950				
CHARACTER OF MATERIAL	(Feet below From	land surface) To	Thickne (feet)		
Clay	0	13	13		
Loose gravel	13	25	12		
Hard pan or cement gravel	25	50	25		
Cement & water gravel	50	70	20		
Hard pan of sand and gravel	70	80	10		
Cement gravel & water gravel	80	100	20		
Water gravel	100	114	14		
Water gravel	114	125	17.		
Loose gravel & sand	125	130	5		
Cement gravel	130	145	15		
Sand & gravel water	145	153	8		
,					