

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
AUG 16 1962
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

MAR 7 1964

State Well No. 5/1W-9

State Permit No. _____

(1) OWNER:

Name Hillcrest Florists
Address 2705 Molalla Road
Woodburn, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number _____
1/4 1/4 Section 9 T. 5S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Drill Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 142 ft. Gage 1/4"
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Millknife
Size of perforations 1/4 in. by 2 in.
30 perforations from 137 ft. to 140 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Beatonite Mud
Depth of seal 30 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 46 ft. below land surface Date 8/1/62
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? driller
Yield: 120 gal./min. with 55 ft. drawdown after 3 hrs.
" " " " "
" " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 52° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 142 ft. Depth of completed well 142 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface	0	3
Brown sandy clay	3	45
Brown sand	45	75
Blue clay	75	90
Gravel	90	95
Blue clay	95	97
Black sand	97	100
Broken sand and gravel	100	109
Blue clay	109	116
Sand (black)	116	132
Broken sand and gravel	132	142

Work started July 21 1962 Completed July 28 1962
Date well drilling machine moved off of well July 30 1962

(13) PUMP:

Manufacturer's Name J.A. Guzzi
Type: Turbine H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller (Type or print)
(Person, firm or corporation)

Address P.O. Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. _____

[Signed] John T. Miller
(Water Well Contractor)

Contractor's License No. 277 Date August 1, 1962