

## STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

MARI

55/2W	123ab
- ,	•

(START CARD) # \_\_\_22694

(1) OWNER: Well Number:	(9) LOCATION OF WELL by legal description:
Name Dean Hammond	County Marion Latitude Longitude Longitude Township 5S Nor S, Range 2W E or W, WM.
Address 4380 Mahony Rd.	Township 5S Nor S, Range 2W E or W, WM.
City St. Paul State OR Zip 97137	Section 23 NW 1/4 NE 1/4
(2) TYPE OF WORK:	Tax Lot 44332-000 Block Subdivision
☐ New Well	Street Address of Well (or nearest address) 7645 Jensen Rd.
(3) DRILL METHOD	Gervais, OR
Rotary Air Rotary Mud & Cable	(10) STATIC WATER LEVEL:
Other	13ft. below land surface. Date 5/8/91
(4) PROPOSED USE:	Artesian pressure lb. per square inch. Date
☐ Domestic ☐ Community ☐ Industrial 🛣 Irrigation	(11) WATER BEARING ZONES:
☐ Thermal ☐ Injection ☐ Other	Depth at which water was first found 129'
(5) BORE HOLE CONSTRUCTION:	
pecial Construction approval Yes No Depth of Completed Well 150' ft.	From To Estimated Flow Rate SWL
Yes No	129' 151' 700 GPM 13
HOLE SEAL Amount Diameter From To Material From To sacks or pounds	
12" 0 21 cement 0 21 56 sacks	(10) WELL TOO
8" 21 153	(12) WELL LOG: Ground elevation
	Material From To SWL
	Existing well 0 129
How was seal placed: Method $\square$ A $\square$ B $\swarrow$ C $\square$ D $\square$ E	Sand & gravel 129 151
Other	Clay, grey 151 153
Backfill placed fromft. toft. Material	
Gravel placed from 150 ft. to 153 ft. Size of gravel pea	
(6) CASING/LINER:	
Diameter From To Gauge Steel Plastic Welded Threaded	
Casing: 8" +1 132 250 X	
Liner:	RFI.FIVEI
Final location of shoe(s) 132	MAY 9 1 1991
7) PERFORATIONS/SCREENS:	
Perforations Method	WATER RESOURCES DEPT.
Screens Type Material stainless	SALEM, OREGON
Slot Tele/pipe	J. L.
From To size Number Diameter size Casing Liner	
126' 130' Packer and 7" Pipe     130'	
130'150'3".100 7" screen $\square$ $\square$ 150'3" Bottom plate and lifting bail $\square$	
	4/19/01
	Date started 4/18/91 Completed 5/8/91
(8) WELL TESTS: Minimum testing time is 1 hour	(unbonded) Water Well Constructor Certification:
Flowing	I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction
☐ Pump ☐ Bailer ※ Air ☐ Artesian	standards. Materials used and information reported above are true to my best
Yield gal/min Drawdown Drill stem at Time	knowledge and belief.
1 hr.	WWC Number
700 150 9 hrs.	Signed Date
	(bonded) Water Well Constructor Certification:
Temperature of water 54 degrees Depth Artesian Flow Found	I accept responsibility for the construction, alteration, or abandonment
Was a water analysis done?	work performed on this well during the construction dates reported above. all work performed during this time is in compliance with Oregon well
Did any strata contain water not suitable for intended use?   Too little	construction standards. This report is true to the best of my knowledge and
☐ Salty ☐ Muddy ☐ Odor ☐ Colored ☐ Other	Signed Tole Research Date May 14, 1991
Depth of strata:	Signed Date