NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 (Please type or point). TEENGINEER Permit No. (Do not write above this first EM CRESCON WATER WELL REPORT CE VENT WELL REPORT CE

(1) OWNER:	(10) LOCATION OF WELL:
Name C H Savage	County Clackamas Driller's well number
Address 4126 S E Milwaukie Ave	14 14 Section 34 T. 3S R. 1W W.M.
Portland, Oregon 97202	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	Doming and amounted room booken or savernment
New Well Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 148 ft.
Rotary Driven Domestic I Industrial Municipal	Static level 51 ft. below land surface. Date 5/9/73
Cable	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded W	(12) WELL LOG: Diameter of well below casing
-	MATERIAL From To SWL
Type of perforator used Millknife	
Size of perforations 5/8 in. by 3½ in.	Surface 0 3
110 perforations from 177 ft. to 182 ft.	22.7811 71.03
perforations from ft. to ft.	Brown sandy clay 27 119 Blue sandy clay 119 135
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? ☐ Yes ₩ No	
Manufacturer's Name	Broken sand & gravel 146 198
Type Model No.	
Diam. Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? 🗷 Yes 🗌 No If yes, by whom? driller	
Yield: 300 gal./min. with 49 ft. drawdown after 8 hrs.	
350 " 70 " 8 "	
" 400 " 95 " 8 "	
Baller test gal./min. with ft. drawdown after hrs.	
tesian flow g.p.m.	
perature of water Depth artesian flow encountered ft.	Work started May 2 19 73 Completed May 9 19 73
(9) CONSTRUCTION:	Date well drilling machine moved off of well 19
Well seal—Material usedCement	Drilling Machine Operator's Certification:
Well sealed from land surface to40ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal18	best knowledge/and belief.
Diameter of well bore below seal1514 in.	[Signed] May 10, 19 73
Number of sacks of cement used in well seal20 sacks	(Drilling Machine Operator)
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No. 26
Brand name of bentonite	Water Wall Contractor's Cartification
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? Tyes No Plugs Size: location ft.	
Did any strata contain unusable water? Yes No	Name John Truman Miller (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address P. 9 Box 341 Hubbard, Oregon 97032
Method of sealing strata off	I was a low of by the
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	[Signed] (Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 277 Date May 10 , 19.73
	. · · · · · · · · · · · · · · · · · · ·