

#114

MARI 17343

RECEIVED

JUL 08 1991

7S/2W/5 dd

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

WATER RESOURCES DEPT. (START CARD) # 25456

(1) OWNER: Name Leonard Schurter Address 9255 Kaufman Rd. NE City Silverton State OR Zip 97381

(2) TYPE OF WORK: [X] New Well [] Deepen [] Recondition [] Abandon

(3) DRILL METHOD: [X] Rotary Air [] Rotary Mud [] Cable [] Other

(4) PROPOSED USE: [] Domestic [] Community [] Industrial [X] Irrigation [] Thermal [] Injection [] Other

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well 237 ft. Special Construction approval Yes No [X] Yes [] No

Table with columns: HOLE Diameter, SEAL Material, Amount sacks or pounds. Rows show Cement and Bentonite seal details.

How was seal placed: Method [] A [] B [X] C [] D [] E. Bentonite poured into dry annulus top 10' after cement settled.

(6) CASING/LINER: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded

Table for casing and liner specifications with columns for diameter, length, gauge, and material type.

(7) PERFORATIONS/SCREENS: [X] Perforations Method Air perforation [] Screens

Table for perforation details with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour. Yield gal/min 360, Drawdown -----, Drill stem at 180, Time 1 hr.

Temperature of water 56, Depth Artesian Flow Found ---, Was a water analysis done? [] Yes [] No

(9) LOCATION OF WELL by legal description: County Marion, Township 7S, Section 5, Street Address of Well Cordon Rd.

(10) STATIC WATER LEVEL: 38 ft. below land surface. Date 6-18-91. Artesian pressure --- lb. per square inch.

(11) WATER BEARING ZONES: Table with columns: From, To, Estimated Flow Rate, SWL. Shows zone from 105 to 235 ft.

(12) WELL LOG: Table with columns: Material, From, To, SWL. Lists soil and geological layers from top soil to clay brown.

Date started 6-12-91 Completed 6-18-91

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards.

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above.