

WATER WELL REPORT
STATE OF OREGON

RECEIVED

MARI
17438

State Well No. 85620/4

State Permit No.

AUG 19 1991 PLEASE TYPE or PRINT IN INK

WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name BEN Bello
Address 1832 59TH SE
City SALEM State OR

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
 Bored Thermal: Withdrawal Reinjection

(5) CASING INSTALLED: Steel Plastic
Threaded Welded
6" Diam. from 1 1/2 ft. to 109 ft. Gauge 2.5
10" Diam. from 0 ft. to 0 ft. Gauge

(6) LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? Yes No

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Well: gal./min. with ft. drawdown after hrs.
Air test 135 gal./min. with drill stem at 217 ft. 6 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes No

Well seal—Material used NEAT CEMENT
Well sealed from land surface to 35 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 23 sacks
How was cement grout placed? PUMPED AS
10 SURFACE CASING WAS PULLED
BACK FROM 35 FT.
Was pump installed? NO Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County MAHON Driller's well number
1/4 Section 7 TER RESOURCES DEPT. W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 1832 59TH SE

(11) WATER LEVEL: Completed well.

Depth at which water was first found 5 ft.
Static level 5 ft. below land surface. Date
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6

Depth drilled 217 ft. Depth of completed well 217 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL GRAY	0	1	
CLAY GRAY	1	5	
CLAY GRAY SANDY	5	16	
SANDY CLAY w/ Basalt	16	21	
SANDY GRAVEL w/ Basalt	21	28	
CLAY BLUE	28	73	
SANDY CLAY w/ GRAVEL	73	84	21
SAND FINE w/ clay	94	103	
BASALT SOFT	103	106	
BASALT HARD MED	106	146	
BASALT HARD	146	177	
BASALT BROKEN FINE	177	187	
BASALT FRACTURED	187	193	27
BASALT BROKEN	193		
WEATHERED		200	
BASALT BROKEN	200	215	
BASALT HARD	215	217	

Work started 4/6 1987 Completed 10/2 1987
Date well drilling machine moved off of well 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Paul Bello Date 11/1 1987

Bonded Water Well Constructor Certification:

Bond (number) Issued by: Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Bello Well Drilling (Type or print)
Address 4771 W. W. R. RD SE
[Signed] Paul Bello Water Well Constructor
Date 11/1 1987