

NOTICE TO WATER WELL CONTRACTOR

The original and first of this report are to filed with the

RECEIVED
JUN 24 1968

STATE OF OREGON WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE ENGINEER SALEM OREGON
Please type or print
(Do not write above this line)

1757
MARI...
State Well No. 5/1w-20
State Permit No.

(1) OWNER:

Name Gred Deeburce
Address Rt # 1, Box 302A, Warden Oregon 97147

(11) LOCATION OF WELL:

County Mason Driller's well number
1/4 1/4 Section 122 T. 5 R. 1 West W.M.
Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

12" Diam. from 0 ft. to 125 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Type of perforator used Mucella Perforated? Yes No.
Size of perforations 3/8 in. by 3 in.
442 perforations from 104 ft. to 124 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 23 ft. below land surface Date 6/4/68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? Huttons
Yield: 900 gal./min. with 88 ft. drawdown after 1 hrs.
600 " 59 " 1 "
500 " 57 " 1 "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Puddle Clay
Depth of seal 25 ft.
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(12) WELL LOG:

Diameter of well below casing
Depth drilled 125 ft. Depth of completed well 125 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	5	
Brown clay	5	30	
Brown sand	30	35	
Blue clay	35	53	
Grey sand	55	70	
Blue clay	70	90	
Brown clay	90	95	
Black silt	95	102	
Black - Water bearing	102	125	

Work started 5/27/68 Completed 6/3/68
Date well drilling machine moved off of well 6/4/68

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J. F. Terrell Date 6/19/68
(Drilling Machine Operator)

Drilling Machine Operator's License No. 179

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. F. Terrell/Neal Drilling
(Person, firm or corporation) (Type or print)

Address Rt #1, Box 57, Coquille Ore.

[Signed] J. F. Terrell
(Water Well Contractor)

Contractor's License No. 460 Date 6/19/68