

(1) OWNER: SALEM OREGON
Name
Address 2295 E. LINCOLN ROAD
Woodburn, Oregon

(2) LOCATION OF WELL:
County Marion Owner's number, if any—
R. F. D. or Street No.
Bearing and distance from section or subdivision corner
273' NORTH AND 154'36" WEST OF THE SE
CORNER OF N 1/2 of E 1/2 of Sec. 14
O.C. # 42 on Sec. 14 T. 25S, R. 11W
WM in Marion County

(3) TYPE OF WORK (check):
 New well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) EQUIPMENT:
Rotary
Cable
Dug Well

CASING INSTALLED:
 Threaded Welded
FROM ft. to ft. Diam. Gage or Wall
Top 134' 2" 8"
" " " " 8 7/8"
" " " " "
" " " " "
" " " " "
Type and size of shoe or well ring
Describe joint Welded Spring Steel 3/2 X 3

(7) PERFORATIONS: Mills
Type of perforator used
SIZE of perforations in. length, by in.
FROM ft. to ft. perf per foot No. of rows
" " " " " " " " "
" " " " " " " " "
" " " " " " " " "
" " " " " " " " "

SCREENS: No Screens
Give Manufacturer's Name, Model No. and Size

(8) CONSTRUCTION: puddled Clay
Was a surface sanitary seal provided? Yes No To what depth 20 ft.
Were any strata sealed against pollution? Yes No
If yes, note depth of strata
FROM ft. to ft.

METHOD OF SEALING

(9) WATER LEVELS:
Depth at which water was first found 65 ft.
Standing level before perforating 23 ft.
Standing level after perforating Static 23 ft.
Log Accepted by:
[Signed] Jacob Kononaba May 5 1956
Owner

(10) WELL TESTS: Amil Beier Lic. #89
Was a pump test made? Yes No If yes, by whom?
Yield: 293 gal./min. with 32 ft. draw down after 6 hrs.
" 140 " " 20 " 6 "

Artesian flow _____ g.p.m.
Shut-in pressure _____ lbs. per square inch.
Bailer test _____ g.p.m. with _____ ft. drawdown
Temperature of water 56 Was a chemical analysis made? Yes No
Was electric log made of well? Yes No

(11) WELL LOG:
Diameter of well, 8 inches.
Total depth 134 ft. Depth of completed well 134 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.
Top ft. to 2 ft. Top Soil
2 " 28 " Yellow Clay
29 " 35 " Yellow silt & clay
35 " 65 " Blue Clay
65 " 70 " Brown Sand small gravel
" " " " " " (Some water)
70 104 " Blue Clay
104 125 " Cemented sand & Gravel
" " " " " " (Very little water)
125 134 " Black Sand & Gravel (Water)

Still drilling in above sand & gravel
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "

Ground elevation at well site 120 feet above mean sea level.
Work started April 10 56 Completed April 24 56

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Willamette Drilling Co.
(Person, firm, or corporation) (Typed or printed)
Address Rt. 2 Box 323 Salem, Oregon
Driller's well number 252
[Signed] Ray Perkins
(Well Driller)
License No. 2 Dated April 28 1956